

Clare Whiting

From: Matthew Phillips
Sent: 22 October 2018 09:20
To: planning_admin
Subject: FW: P/2018/0817

Please add as flood officer comments

From: Neil Taunt
Sent: 17 October 2018 10:44
To: Matthew Phillips
Subject: P/2018/0817

Hi Matthew,

I have reviewed the submitted documents in relation to the discharge of condition 13.

I have no objections to the principle of the scheme, with the demonstrated discharge rate and attenuation provision on site being consistent with our standard requirements.

No information has been submitted in relation to parts ii and iii of condition 13. This is in relation to responsibilities for implementation of the scheme and associated timing and the arrangement for future maintenance of different elements of the scheme. I would request this information is submitted prior to commenting further.

Many thanks

Neil

Neil Taunt MCIWEM C.WEM CEnv CSci
Uwch Swyddog Rheoli Llifogydd / Senior Flood Management Officer



01978 729734 / 07808 787632

Amgylchedd a Chynllunio, Cyngor Bwrdeistref Sirol Wrecsam, De Ffordd yr Abaty, Ystad Ddiwydiannol Wrecsam, Wrecsam LL13 9PW

Environment & Planning, Wrexham County Borough Council, Abbey Road South, Wrexham Industrial Estate, Wrexham LL13 9PW

wrecsam.gov.uk | wrexham.gov.uk

twitter.com/cbswrecsam | twitter.com/wrexhamcbc

facebook.com/cyngorwrecsam | facebook.com/wrexhamcouncil