

MEMORANDUM

From: Ian Jones Public Protection
Service Manager

To: David Williams Planning
Control Manager

Our Ref:

Your Ref: P/2018/0877

Date: 01-11-2018

Town and Country Planning Act 1990

Town and Country Planning (General Development Procedure) Order 1996

Re: P/2018/0877, FORMER CHAPEL THE HOMESTEAD MOUNT STREET RHOSTYLLLEN WREXHAM

CONVERSION OF FORMER CHAPEL TO GROUND FLOOR SALON AND FIRST FLOOR RESIDENTIAL UNIT

Contaminated Land

ZP01B - Contaminated Land - Phased Investigation

Due to the potential for contamination issues as a result of historical use (Garage Repair Business) of the land/building it will be necessary to ensure that any future planning consent is conditioned so as to ensure that any potential contamination issues are adequately dealt with. I would recommend the following Conditions and Note to Applicant be applied to any future consent that may be granted.

Condition

No development shall take place until a phased site investigation of the nature and extent of contamination has been carried out and submitted to and approved in writing by the Local Planning Authority. If any contamination is found during the site investigation, no part of the development shall commence until a scheme specifying the measures that will be taken to remediate the site to render it suitable for the development hereby permitted has been submitted to and approved in writing by the local planning authority. The site shall thereafter be remediated in accordance with the approved scheme. If during the course of development any contamination is found that has not been identified in the site investigation, no further development shall take place on those parts of the site where that contamination has been found until an additional scheme of remediation has been submitted to and approved in writing by the local planning authority for those parts of the site. The relevant parts of the site shall thereafter be remediated in accordance with the additional scheme of remediation.

ZP02A - Verification Report - Contaminated Land

Each part of the site subject to the remediation under the scheme(s) approved as part of condition @@ shall not be

occupied/used until a Validation Report has been completed in respect of that part of the site and submitted to and approved in writing by the Local Planning Authority.

A11NA - SITE CONTAMINATION

Further advice on compliance with condition no. @@ may be obtained by contacting the Council's Environmental Protection Team on 01978 298989 or contaminatedland@wrexham.gov.uk. Should the investigation identify contamination issues that may affect receptors other than the site users e.g. groundwater, then it is recommended that these works are also addressed in consultation with the Council's Environmental Protection Team prior to commencement of works on site.

Environmental Protection

ZP04 - AIR HANDLING / EXTRACTION PLANT BS4142 ASSESSMENT

If air handling plant is proposed:

The rating level of any noise generated by air handling plant associated with the development shall not exceed the pre-existing background level by more than 5dB(A) at any time. The noise levels shall be determined at nearby noise sensitive premises, and measurements and assessment shall be made in accordance with BS4142:2014 Methods for rating and assessing industrial and commercial sound.

A22NA - MINOR DEVELOPMENT CONSTRUCTION NOISE

All works in relation to the implementation of this permission, including deliveries to and /or leaving the site, should be undertaken only between the hours of 07.30 to 18.00 Monday to Friday, 08.00 to 14.00 on a Saturday, and at no time on a Sunday or a Bank Holiday. Outside these times, any works which are audible beyond the site boundary have the potential to cause unreasonable disturbance to neighbouring premises.

The applicant is advised that the Council has the option to control construction noise by serving a Control of Pollution Act 1974, Section 60, Notice where deemed necessary, and failure to comply with such a Notice can result in prosecution.

The applicant should adhere to the times given above wherever possible. For further information and advice regarding construction noise please contact the Council's Environment and Planning Department on 01978 292040.

.....

Head of Planning and Environment