

Clare Whiting

From: Philip Forster
Sent: 16 May 2018 08:28
To: planning_admin
Subject: FW: P/2018/0309

Consultation response

From: Neil Taunt
Sent: 16 May 2018 06:26
To: Philip Forster
Subject: P/2018/0309

Hi Phil,

Hopefully I'm not too late to comment on the above application?

The information submitted in support of discharge of condition 11 indicates existing soakaways will be used to discharge surface water generated by the new development. No information is included in relation to existing capacity or effectiveness of the soakaways, as such I am not able to comment on the suitability of the proposal and am unable to recommend the condition be discharged at this time.

Thanks

Neil

Neil Taunt MCIWEM C.WEM CEnv CSci

Uwch Swyddog Rheoli Llifogydd / Senior Flood Management Officer



☎ 01978 729734 / 07808 787632

✉ Amgylchedd a Chynllunio, Cyngor Bwrdeistref Sirol Wrecsam, De Ffordd yr Abaty, Ystad Ddiwydiannol Wrecsam, Wrecsam LL13 9PW

📍 Environment & Planning, Wrexham County Borough Council, Abbey Road South, Wrexham Industrial Estate, Wrexham LL13 9PW

🌐 wrecsam.gov.uk | wrexham.gov.uk

🐦 twitter.com/cbswrecsam | twitter.com/wrexhamcbc

📘 facebook.com/cyngorwrecsam | facebook.com/wrexhamcouncil