

Cerys Jones

From: Sharon Holman
Sent: 15 June 2018 08:48
To: planning_admin
Subject: FW: P/2018/0403 2B Greystones Church Street Chirk LL14 5HA

Importance: High

[Civ - additional info](#)

From: Chris Hargreaves [<mailto:c.hargreaves@nockdeighton.co.uk>]
Sent: 14 June 2018 17:09
To: Ian1 Jones
Cc: David Williams; Sharon Holman
Subject: P/2018/0403 2B Greystones Church Street Chirk LL14 5HA
Importance: High

Dear Mr Jones

Further to my application above I noted that you required details of the ventilation for extraction and dispersal of cooking smells etc.

The kitchen measures 1.93m x 3.52m and with normal ceiling height the volume of the room is approximately 14 cubic metres.

The kitchen will have a normal domestic electric four ring cooker, microwave and coffee machine. No heavy duty machinery involved.

The air extractor fan proposed is a Manrose commercial extractor fan (type WF150AP) – white plastic with square external grille and pull cord operated.

It will be window mounted – the window also has an opening window lite.

It is compliant with Parts F and L of the building regulations. Extraction rate of 220 cubic metres, noise level 40 dba at 3m, thermal overload protection.

Therefore will an air handling / extraction plant BS4142 assessment be necessary?

I have copied this information to the planning officers.

I look forward to your reply with any further comments, advice and guidance.

Regards Chris Hargreaves

Email: cghargreaves@aol.com
Tel: 07970131944