

Susan Davies

From: Matthew Phillips
Sent: 30 April 2018 08:59
To: planning_admin
Subject: FW: Soakways Bryn Celyn

Flood Officer comments P/2018/0019

-----Original Message-----

From: Neil Taunt
Sent: 30 April 2018 08:56
To: 'Steve Barnett'
Cc: Matthew Phillips
Subject: RE: Soakways Bryn Celyn

Hi Steve,

Thank you for the additional calculations incorporating the 1% (1 in 100 year) rainfall event. I am now satisfied that the soakaway design meets our normal requirements.

Many thanks

Neil

-----Original Message-----

From: Steve Barnett [<mailto:steve@barnettengineering.co.uk>]
Sent: 10 April 2018 15:11
To: Neil Taunt
Cc: Matthew Phillips
Subject: FW: Soakways Bryn Celyn

Hi Neil,

Please find attached the soakaway pit calculations for The Paddock, Bryn Celyn, Garth as discussed with my father (Barry) based on the 100 year rainfall figures.

I have increased the soakaway pit size to 3.5m 1.5m x 1.5m and this meets all of the calculation criteria.

Please let me know if you require any additional information.

Kind regards,

Steve Barnett

01978 842800

07734476528

-----Original Message-----

From: Sian Barnett
Sent: 10 April 2018 15:03
To: Steve Barnett <steve@barnettengineering.co.uk>
Subject: Soakways Bryn Celyn

Your message is ready to be sent with the following file or link attachments:

Soakways Bryn Celyn

Note: To protect against computer viruses, e-mail programs may prevent sending or receiving certain types of file attachments. Check your e-mail security settings to determine how attachments are handled.