

Cerys Jones

From: Sharon Holman
Sent: 16 March 2018 09:59
To: planning_admin
Subject: FW: P/2018/0063 and 64 Tudor Drive, Penley

Civ – floor officer response to both files please

From: Neil Taunt
Sent: 16 March 2018 09:46
To: Sharon Holman
Cc: Emma Broad
Subject: RE: P/2018/0063 and 64 Tudor Drive, Penley

Hi Sharon,

I have reviewed the maintenance plan for the site and am still not certain as to the function of the attenuation lagoon. If it is only for the attenuation of surface waters then additional information on desilting and vegetation management to maintain attenuation volume over the lifetime of the development is required.

Any additional questions then please let me know.

Thanks

Neil

From: Sharon Holman
Sent: 12 March 2018 09:24
To: Neil Taunt; Emma Broad
Subject: FW: P/2018/0063 and 64 Tudor Drive, Penley

Dear both,

Please see attached drainage maintenance strategy for your consideration. Could I have your comments by the end of the week please?

Thank you
Sharon

From: Almar Construction LTD [<mailto:almarconstruction@aol.co.uk>]
Sent: 09 March 2018 11:41
To: Sharon Holman
Cc: Neil Taunt
Subject: Tudor Drive, Penley

Dear Sharon

I am pleased to attach the maintenance plan that will be undertaken by Greenfields (Tudor Drive) Management LTD for the lifetime of the development. I have copied in Mr. Taunt.

Please come back to me to confirm safe receipt and if you have any queries please do not hesitate to contact us.

Regards

Julie

Almar Construction LTD
Unit 3 Marlowe Court
Whitchurch Business Park
Whitchurch
Shropshire
SY13 1QR

Tel: 01270 440 045