

Clare Whiting

From: Sharon Holman
Sent: 21 May 2018 09:01
To: planning_admin
Subject: FW: P/2018/00289 & 0290

Civ – flood officer resp to both files please

From: Neil Taunt
Sent: 16 May 2018 06:10
To: Sharon Holman
Subject: P/2018/00289 & 0290

Hi Sharon,

Thank you for the recent consultation on the above discharge of condition.

It would appear that the proposed surface water attenuation scheme has now been amended include underground storage. Reference is made to microdrainage calculations that do not appear to be included with the submission. These are required prior to being able to comment on the proposed drainage system. In addition I note that WW/DC are now objecting to the proposed connection to the surface water system. An agreed discharge point, along with details of how the amended system will be managed and maintained, must be demonstrated prior to being able to comment further.

Many thanks

Neil

Neil Taunt MCIWEM C.WEM CEnv CSci
Uwch Swyddog Rheoli Llifogydd / Senior Flood Management Officer



01978 729734 / 07808 787632

Amgylchedd a Chynllunio, Cyngor Bwrdeistref Sirol Wrecsam, De Ffordd yr Abaty, Ystad Ddiwydiannol Wrecsam, Wrecsam LL13 9PW

Environment & Planning, Wrexham County Borough Council, Abbey Road South, Wrexham Industrial Estate, Wrexham LL13 9PW

wrecsam.gov.uk | wrexham.gov.uk

twitter.com/cbswrecsam | twitter.com/wrexhamcbc

facebook.com/cyngorwrecsam | facebook.com/wrexhamcouncil