

Susan Davies

From: Sharon Holman
Sent: 23 May 2018 09:43
To: planning_admin
Subject: P/2018/0370 - Regent Street
Attachments: 10313-10A Elevation and Window Details rev A 1-50 and 1-20atA1.pdf;
ProdData_AluminiumGutters.cleaned.pdf

Civ – add info below and amended plans web attached. Can I have a paper copy for the file please?

Thanks

From: Steve Jones [mailto:DSJonesandCo@live.co.uk]
Sent: 23 May 2018 09:30
To: Sharon Holman
Cc: ianharding65@yahoo.co.uk; Susan Davies
Subject: Fw: MESSAGE FROM SHARON HOLMAN

This email's attachments were cleaned of potential threats by Wrexham Council's Security Gateway.
Click [here](#) if the original attachments are required (justification needed).

Hi Sharon,

Thank you for your email on Monday. I would comment as follows :-

1. The slate which has been proposed is the same slate which was shown to Anna when she visited site a few weeks ago. At the time she seemed comfortable with the choice.
2. I have amended the attached drawing to show a lime mortar for the re-pointing of the bed joints above and below the sandstone plinths / dressings. Elsewhere I have stuck with the sand / cement mortar because this is what is in place at present and also because the brickwork is particularly hard and it would be inappropriate to re-point the bed and perpend joints with a lime based mortar.
3. The drawing has been revised to indicate beaded half round aluminium gutters coloured black by Alumasc or similar equivalent. A copy of the Technical Manual is attached for your information. There are no rainwater downpipes to the front elevation because there is no point of discharge. The collected rainwater is piped through the building and discharged to the rear as per the previous arrangements.
4. The drawing has been amended and is attached.

I trust that this is all in order and look forward to hearing from you again shortly.

Best regards

Steve

From: Susan Davies <Susan.Davies@wrexham.gov.uk>
Sent: 21 May 2018 14:52

To: 'dsjonesandco@live.co.uk'

Subject: MESSAGE FROM SHARON HOLMAN

I have copied and pasted Sharon's email so that you can receive and open it without a password!

Hi Steve,

I have received the advice of the conservation officer as follows...

1. A natural Welsh slate should be used in preference to a Spanish slate;
2. A lime/sand mortar should be used for any re-pointing works to the front elevation. This is particularly important in areas around the sandstone dressings which are quite friable and would benefit from a softer mortar mix;
3. A specification for the replacement rainwater goods is required;
4. A slim profile glazing unit should be used to enable the incorporation of a solid glazing bar to match the proportions of the existing rather than the standard glazing unit and plant on bars proposed.

I would be grateful to receive the above as soon as possible.

Kind regards
Sharon

Sharon Holman
Development Control Planning Officer/ Swyddog Cynllunio Rheoli Datblygu
01978 298779
Wrexham County Borough Council, 16 Lord Street, Wrexham,
LL11 1LG
Cyngor Bwrdeistref Sirol Wrecsam, 16 Stryt yr Arglwydd, Wrecsam,
LL11 1LG
wrexham.gov.uk | wrecsam.gov.uk
twitter.com/wrexhamcbc | twitter.com/cbswrecsam
facebook.com/wrexhamcouncil | facebook.com/cyngorwrecsam

Regards,

Susan Davies

Swyddog Cefnogi Busnes/ Business Support Officer
Rheoli Datblygu/ Development Control



01978 298742



Wrexham County Borough Council, 16 Lord Street, Wrexham LL11 1LG

 Cyngor Bwrdeistref Sirol Wrecsam, 16 Stryt yr Arglwydd, Wrecsam LL11 1LG
 wrexham.gov.uk | wrecsam.gov.uk
 twitter.com/wrexhamcbc | twitter.com/cbswrecsam
 facebook.com/wrexhamcouncil | facebook.com/cyngorwrecsam

To make a payment for a Planning Service please click on the link below:-
www.wrexham.gov.uk/planningfees

I wneud taliad ar gyfer Gwasanaeth Cynllunio cliciwch ar y ddolen isod os gwelwch yn dda : -
www.wrecsam.gov.uk/ffioeddcynllunio

Rydym yn croesawu gohebiaeth yn Gymraeg. Byddwn yn ymateb i unrhyw ohebiaeth yn Gymraeg ac ni fydd hyn yn arwain at unrhyw oedi.

Ewch i weld - mi fedrwch chi dalu, rhoi gwybod, gwneud cais, dweud eich dweud, a dod o hyd i wybodaeth ar-lein yn www.wrecsam.gov.uk. Arbedwch bapur - meddylwch cyn argraffu!

Mae'r neges e-bost hon ac unrhyw atodiadau wedi eu bwriadu ar gyfer yr unigolyn neu'r sefydliad y?i cyfeirir atynt yn unig. Am yr amodau llawn yngl?n ? chynnwys a defnyddio?r neges e-bost hon, ac unrhyw atodiadau, cyfeiriwch at www.wrecsam.gov.uk/top_navigation/disclaimersw.htm

We welcome correspondence in Welsh. We will respond to any correspondence in Welsh and this will not lead to any delay.

Take a look - you can pay, report, request, have your say and find information online at www.wrexham.gov.uk. Save paper - think before you print!

This e-mail message and any attachments are intended solely for the individual or organisation to whom it is addressed. For full conditions in relation to content and use of this e-mail message and any attachments, please refer to www.wrexham.gov.uk/top_navigation/disclaimers.htm