

Cerys Jones

From: Matthew Phillips
Sent: 19 March 2018 09:57
To: planning_admin
Subject: FW: P/2017/0919

Flood Officer comments

From: Neil Taunt
Sent: 19 March 2018 09:56
To: Matthew Phillips
Subject: RE: P/2017/0919

Matthew.

I have recently received an application for consent to divert the existing culvert away from the proposed extension. These diversion works would need to be complete prior to any works commencing on the extension of Unit 55. A suitably worded condition to ensure this would be acceptable in this instance. As per my comments below – this would be in addition to the standard surface water condition.

Regards

Neil

From: Matthew Phillips
Sent: 15 March 2018 14:25
To: Neil Taunt
Subject: RE: P/2017/0919

Neil,

As I understand it they want to divert the culvert. Are you happy for the application to proceed on that basis?

Regards

Matthew Phillips
Planning Control Lead/Arweinydd Rheoli Cynllunio
Environment and Planning/Amgylchedd a Chynllunio
Wrexham County Borough Council/Cyngor Bwrdeistref Sirol Wrecsam
Telephone/Ffôn: 01978 298780

From: Neil Taunt
Sent: 13 March 2018 09:21
To: Matthew Phillips
Subject: RE: P/2017/0919

Matthew,

Response attached.

Regards

Neil

From: Matthew Phillips
Sent: 12 March 2018 16:00
To: Neil Taunt
Subject: FW: P/2017/0919

Neil,

Can you advise what your response is to the correspondence you have exchanged on this matter?

Regards

Matthew Phillips

Planning Control Lead/Arweinydd Rheoli Cynllunio
Environment and Planning/Amgylchedd a Chynllunio
Wrexham County Borough Council/Cyngor Bwrdeistref Sirol Wrecsam
Telephone/Ffôn: 01978 298780

From: Peter Fisk [<mailto:peter.fisk@lovelockmitchell.com>]
Sent: 09 March 2018 12:19
To: Matthew Phillips
Subject: RE: P/2017/0919

Matthew,

Given the content of the attached email correspondence between OPUS' Civil Engineer and Neil Taunt, and my previous email pertaining to NRW comments is there now anything impeding a planning decision being made?

Please advise.

Regards,
Peter Fisk
Associate



3 Stanley Street, Chester, CH1 2LS
Tel: +44 (0) 1244 404321
Mobile: 07734 869740
www.lovelockmitchell.com
Excellence in architecture since 1862



RIBA Chartered Practice



ISO 9001:2015



Constructionline



Revit Certified Professionals

From: Matthew Phillips [<mailto:Matthew.Phillips@wrexham.gov.uk>]
Sent: 09 March 2018 11:56
To: Peter Fisk <peter.fisk@lovelockmitchell.com>
Subject: FW: P/2017/0919

Peter,

See below – following the clarification I sought from our Flood Officer.

From: Neil Taunt
Sent: 08 March 2018 13:32
To: Matthew Phillips
Subject: RE: P/2017/0919

Matthew,

I have now had opportunity to review the submitted FCA. I will leave any comments on the adequacy of the modelling etc to NRW, but I do have fundamental concerns regarding building over of the existing culverted watercourse and object to the proposed development in its current form.

With regards to the proposed extension to unit 55, this will clearly extend over the line of the existing culverted watercourse that crosses the site. In accordance with the attached guidance note regarding culverts, there is a presumption against building over existing culverts. If the site proposal can not accommodate the existing culvert then I would expect the line of the culvert to be diverted, preferably into an open channel if possible within the site constraints. Any proposal to divert the existing culvert, be it into a new open channel or covered culvert, would need to demonstrate no adverse impact on flood risk locally. The applicant should also be advised that additional consent will be required under the Land Drainage Act for any works to the existing culvert. This position has been previously made to consultants Opus International work on behalf of the applicant.

Revised details of how the culvert will be incorporated into the proposed development should be submitted that do not incorporate building over the exist structure – be this restoration into an open channel or diversion of the culverted watercourse (supported by information to demonstrate no adverse impact locally). In the absence of this information I request that the application be refused.

If the above issue can be resolved I am satisfied in this instance (due to the accessibility of the watercourse) that a suitably worded condition can secure a sustainable means of surface water disposal.

If you have any questions on the above please let me know.

Many thanks

Neil

From: Matthew Phillips
Sent: 06 March 2018 13:01
To: Neil Taunt
Subject: P/2017/0919

Neil,

Please see attached. What is your view on this? The development will occupy the site of a relatively recently demolished building, would that make a difference?

Regards

Matthew Phillips

Planning Control Lead/Arweinydd Rheoli Cynllunio
Environment and Planning/Amgylchedd a Chynllunio
Wrexham County Borough Council/Cyngor Bwrdeistref Sirol Wrecsam
Telephone/Ffôn: 01978 298780

Rydym yn croesawu gohebiaeth yn Gymraeg. Byddwn yn ymateb i unrhyw ohebiaeth yn Gymraeg ac ni fydd hyn yn arwain at unrhyw oedi.

Ewch i weld - mi fedrwch chi dalu, rhoi gwybod, gwneud cais, dweud eich dweud, a dod o hyd i wybodaeth ar-lein yn www.wrecsam.gov.uk. Arbedwch bapur - meddyliwch cyn argraffu!

Mae'r neges e-bost hon ac unrhyw atodiadau wedi eu bwriadu ar gyfer yr unigolyn neu'r sefydliad y?i cyfeirir atynt yn unig. Am yr amodau llawn yngl?n â chynnwys a defnyddio'r neges e-bost hon, ac unrhyw atodiadau, cyfeiriwch at www.wrecsam.gov.uk/top_navigation/disclaimersw.htm

We welcome correspondence in Welsh. We will respond to any correspondence in Welsh and this will not lead to any delay.

Take a look - you can pay, report, request, have your say and find information online at www.wrexham.gov.uk. Save paper - think before you print!

This e-mail message and any attachments are intended solely for the individual or organisation to whom it is addressed. For full conditions in relation to content and use of this e-mail message and any attachments, please refer to www.wrexham.gov.uk/top_navigation/disclaimers.htm