

MEMORANDUM

From: Ian Jones Public Protection
Service Manager

To: David Williams Planning
Control Manager

Our Ref:

Your Ref: P/2018/0152

Date: 06-03-2018

Town and Country Planning Act 1990

Town and Country Planning (General Development Procedure) Order 1996

Re: P/2018/0152, MAGELLAN AEROSPACE RACKERY LANE LLAY WREXHAM

INSTALL VENTILATION AND EXTRACTION DUCTING / STACK, REPLACE ROLLER SHUTTER DOOR WITH CLADDING WHERE DUCTING EXITS BUILDING (RETROSPECT)

Contaminated Land - No Comments

No Comments

ZP04 - AIR HANDLING / EXTRACTION PLANT BS4142 ASSESSMENT

The rating level of any noise generated by air handling plant associated with the development shall not exceed the pre-existing background level by more than 5dB(A) at any time. The noise levels shall be determined at nearby noise sensitive premises, and measurements and assessment shall be made in accordance with BS4142:2014 Methods for rating and assessing industrial and commercial sound.

Environmental Protection - No Comments

The applicant holds a permit with WCBC to operate an A2 process. The applicant is advised to contact the Environmental Protection department of the Council to discuss any effects or changes the change highlighted in this application has on the permit. Failure to do so may result in the applicant being in breach of the permit requirements and liable to further enforcement action.

.....

Head of Planning and Environment