

Wrexham County Borough Council

Date: 26th February 2018

Ebost/Email: Northplanning@cyfoethnaturiolcymru.gov.uk
Ffôn/Phone: (0300) 065 3787

Dear Sir/Madam,

CHANGE OF USE OF REDUNDANT PRIVATE SWIMMING POOL ATTACHED TO ISCOYD HOUSE TO FORM 2 NO. HOLIDAY APARTMENTS ISCOYD HOUSE, BROOMERS LANE, ISCOYD, WHITCHURCH

Thank you for referring the above planning application received at our office 23rd February 2018.

NRW would not object to these proposals as we consider they are unlikely to have a significant adverse effect upon the interests listed.

Foul Drainage

Government policy states that, where practicable, foul drainage should be discharged to the mains sewer. Where this is not possible and private sewage treatment / disposal facilities are utilised, they must be installed and maintained in accordance with British Standard 6297 and Approved Document H of the Building Regulations 2000. You should also have regard to Welsh Office Circular 10/99 in respect of planning requirements for non mains sewerage.

The written consent of NRW or registration for exemption by the developer will be required for any discharge e.g. foul drainage to a watercourse/ditch etc, from the site and may also be required for certain categories of discharges to land. All necessary NRW consents, or exemptions must be obtained prior to works progressing on site.

You will need to apply for a Permit or Exemption, if you wish to discharge anything apart from uncontaminated surface water to a watercourse/ditch. You may also need to apply for a Permit from our National Permitting Team to allow certain discharges into ground. You must obtain any necessary Permit prior to works starting on site. The Welsh Government has also advised that all septic tanks and small sewage treatment plant discharges in Wales will need to be registered. More information, including a step by step guide to registering, is available on our website www.naturalresourceswales.gov.uk / www.cyfoethnaturiolcymru.gov.uk

Pollution Prevention

Due to the proximity of the site to watercourses, all works at the site must be carried out in accordance with GPP5 and PPG6: 'Works in, near or over watercourses' and 'Working at construction and demolition sites' which are available on the following website:

<http://www.netregs.org.uk/environmental-topics/pollution-prevention-guidelines-ppgs-and-replacement-series/guidance-for-pollution-prevention-gpps-full-list/>

Our comments above only relate specifically to matters that are included on our checklist "Natural Resources Wales and Planning Consultations" (March 2015) which is published on our website: (<https://naturalresources.wales/planning-and-development/planning-and-development/?lang=en>). We have not considered potential effects on other matters and do not *rule out the potential for the proposed development to affect other interests, including environmental interests of local importance*. The applicant should be advised that, in addition to planning permission, it is their responsibility to ensure that they secure all other permits/consents relevant to their development.

Please do not hesitate to contact us if you require further information or clarification on any of the above.

Yn gywir / Yours' faithfully,



Ruth Prichard

Ymgynghorydd Cynllunio Datblygu / Development Planning Advisor

Ebost/Email: Ruth.Prichard@cyfoethnaturiolcymru.gov.uk

Deialu uniongyrchol/Direct dial: (0300) 065 3787 **Siaradwr Cymraeg / Welsh Speaker**



cc: