

AnnS Jones

From: Matthew Phillips
Sent: 27 September 2016 15:02
To: planning_admin
Subject: FW: Message from P5449

Highways response to P/2016/0585

From: Peter Douthwaite
Sent: 27 September 2016 14:55
To: Matthew Phillips
Subject: RE: Message from P5449

This is pretty much what I requested.

Plan shows double yellows on Brynydd only – needs a scheme along Fennant Road as well - but this is covered by the suggested planning condition

My response requested 2m footway along whole site frontage – I agreed on site that the Brynydd footway can be reduced to 1.6m – not sure if condition needs altering?

Position of bollards and tactiles needs amending but this can be done under S278 agreement

Pete

From: Matthew Phillips
Sent: 27 September 2016 13:33
To: Peter Douthwaite
Subject: FW: Message from P5449

Pete,

See attached – amended plan for P/2016/0585. This should be to scale if you print at A3. How does this look?

Regards

Matthew Phillips

Planning Officer/Swyddog Cynllunio
Environment and Planning/Amgylchedd a Chynllunio
Wrexham County Borough Council/Cyngor Bwrdeistref Sirol Wrexham
Telephone/Ffôn: 01978 298780

From: Matthew.Phillips@wrexham.gov.uk [<mailto:Matthew.Phillips@wrexham.gov.uk>]
Sent: 27 September 2016 13:27
To: Matthew Phillips
Subject: Message from P5449