

AnnS Jones

From: Sharon Holman
Sent: 30 August 2016 16:17
To: planning_admin
Subject: FW: P/2016/0800

Civ – flood officer resp

From: Neil Taunt
Sent: 30 August 2016 16:14
To: Sharon Holman
Subject: P/2016/0800

Hi Sharon,

I don't think I was consulted on this application originally.

It would appear that Welsh Water have requested a condition with regards to drainage. The proposed drawing would appear to suggest surface water will discharge to combined sewer, with no justification of why other methods of disposal have been discounted, or justification for the sizing of the attenuation system proposed. I would recommend Welsh Waters views are sought on this discharge of condition.

Many thanks

Neil

Neil Taunt MCIWEM C.WEM CEnv CSci

Senior Flood Management Officer / Uwch Swyddog Rheoli Llifogydd



☎ 01978 729734

✉ Environment & Planning, Wrexham County Borough Council, Abbey Road South, Wrexham Industrial Estate, Wrexham LL13 9PW

✉ Amgylchedd a Chynllunio, Cyngor Bwrdeistref Sirol Wreccsam, De Ffordd yr Abaty, Ystad Ddiwydiannol Wreccsam, Wreccsam LL13 9PW

🌐 wrexham.gov.uk | wreccsam.gov.uk

🐦 twitter.com/wrexhamcbc | twitter.com/cbswreccsam

📘 facebook.com/wrexhamcouncil | facebook.com/cyngorwreccsam