

MEMORANDUM

From:	Service Manager Environment	To:	Head of Community Well-being and Development
Our Ref:	P/2016/0328	Your Ref:	P/2016/0328
Date:	17 May 2016		

Location: O. S Grid Ref: 3017 4372 The Old Bakery, Duke Street, Ruabon
Development: Erection of natural timber vertical feathered fence (3' high approximately) on top of existing wall

I refer to your consultation 26 April 2016 in respect of the above.

The location of the proposed fence does not obstruct any lateral or forward highway visibility requirements.

However the wall on which the fence is to be erected is presumed to be a highway retaining structure. The Council does not permit the erection of a privately owned fence on top of a highway retaining wall.

I therefore recommend that the application is refused.

Peter Dorkin

P Service Manager Environment