

AnnS Jones

From: Matthew Phillips
Sent: 13 May 2016 11:09
To: planning_admin
Subject: FW: P/2016/0378

Public Protection response

From: Nick Minshall
Sent: 10 May 2016 09:49
To: Matthew Phillips
Subject: RE: P/2016/0378

Hello Matthew

I confirm that the proposed plant noise levels demonstrate compliance with the noise condition.

Regards Nick

From: Matthew Phillips
Sent: 10 May 2016 09:12
To: Nick Minshall
Subject: P/2016/0378

Nick,

I have recieved the above submission – it has been made in order to comply with condition 14 of planning permission P/2012/0830. The condition specifies the following:

The rating level of any noise generated by air handling plant associated with the development shall not exceed the pre-existing background level by more than 5dB(A) at any time. The noise levels shall be determined at the nearest noise sensitive premises and measurements and assessment shall be made in accordance with BS4142:1997 'Method of Rating Industrial Noise Affecting Mixed Residential and Industrial Areas'

Strictly speaking the applicants don't actually need to make any submissions, but have chosen to anyway. Can you have a look at what has been submitted and let me know if it demonstrates compliance with the condition. Please note that there is a separate condition imposed upon permission P/2012/0830 (permission 13):

The building shall not be occupied until the acoustic fence has been fully erected in accordance with drawing number 3405-P08 Rev C and the Noise Assessment (dated 11 November 2012). The acoustic fence shall thereafter be permanently retained.

The acoustic fence the condition requires will enclose the service yard and the area where the plans that have been submitted with the current noise assessment.

Regards

Matthew