

MEMORANDUM



From: Head of Housing, Public
Protection and Environment

To: Head of Community
Wellbeing and Development

Our Ref:

Your Ref: P/2016/0299

Date: 11-04-2016

Town and Country Planning Act 1990

Town and Country Planning (General Development Procedure) Order 1996

Re: P/2016/0299, CHANGE OF USE FROM WORKSHOP TO STORAGE AND DISTRIBUTION (USE CLASS B8)

Contaminated Land

No Comments

Environmental Protection

ZP05 - NOISE GENERATION - BS4142 REQUIRED

The rating level of any noise generated by reason of this development shall not exceed the pre-existing background level by more than 5dB(A) at any time. The noise levels shall be determined at nearby noise sensitive premises, and measurements and assessment shall be made in accordance with BS4142:2014 Methods for rating and assessing industrial and commercial sound.

Additionally, an appropriate restriction on the permissible hours for HGV deliveries/departures

.....

Head of Housing, Public Protection and Environment

Enc.