

Street Lighting 4 NUMBER
Column: 6m tubular steel column type
CU Phosco 5mm base 3mm shaft
Lantern: post top mounted PHOSCO P56/7A LED
06-NW-B500-Standard-FG-33W
Gear: standard integral gear
PECU: SELC SELC ARCO mini cell set to switch
on at 35 lux with a 2 to 1 negative switching
ratio.

All Columns to be Serviced with Distribution
Network Cut Out.

All Columns must have a Tofoco type
isolator fitted above the DNO Cut Out
IDNO installations need to advise Wrexham
Council prior to installation.

IDNO details must be issued to the Council's
street lighting department.

IDNO emergency details must be visible in the
base of each column

All work to be in accordance with Wrexham
Specification 2015.

It is the contractors responsibility to undertake
a full risk assessment prior to the columns
being erected.

KANE DESIGN
Civil Engineering Design

15 Whinbottle Way
Gresford
Wrexham
LL12 8HH

Tel: 01 978 835888

Project
PROPOSED DEVELOPMENT at
CHESTNUT COURT, SUMMERHILL, WREXHAM

Title			
HIGHWAYS SECTION 38			
DRAWING NUMBER		SCALE	
1261-22		1:250	@ A1
DATE	14/09/15	REVISION	
DRAWN	AK		
CHECKED	AK		
			D

