

From: Sharon Holman
To: planning_admin
Date: 21/09/2010 12:56
Subject: Fwd: Re: P/2010/0537 - Rehoboth Gospel Hall, Heol Kenyon, Johnstown
Place: planning_admin

please import the further highway response

>>> Peter Douthwaite 21/09/2010 11:23 >>>
Sharon

The site is currently accessed by driving over a 2.3m wide publicly adopted footway creating potential for conflict between vehicles and pedestrians using this substandard access.

Although it is considered that this proposal is unlikely to generate increased traffic movements at the site it would nevertheless, given the substandard nature of the access, be desirable to prevent continued vehicular access over the footway.

As there is clear highway safety benefit in abandoning use of the existing access in favour of access via Heol Ddyfrdwy I confirm my support for this proposal.

Pete

>>> Sharon Holman 16/09/2010 10:29 >>>
Hi Pete,

I am reporting this one to the October committee with a recommendation for approval. As this existing access is substandard, I think there would be a benefit in terms of highway safety if we supported the proposal to permanently abandon the existing vehicular access in favour of an access onto the adopted highway to the rear of Heol Ddyffrdwy.

Could I please have your written views on this so that I can include in the committee report?

Thank you
Sharon