

FOUNDATION DESIGN – BUILDING 5 FDPF

The new Building 5 is to be constructed to the south of existing Building 2, the rear (west) of Building 1. Foundations are to be pad footings located at about 1.8 -2.0m depth in the firm to stiff clay of the Glacial Till deposits as shown on drawing no. 20382-CIV-DRG-1601-T0.

It is not proposed to use piling or any other foundation designs using penetrative methods for this building structure.

Mark Fairhurst CEng MICE

KMG

31 March 2021