

Cerys Jones

From: Sharon Holman
Sent: 09 July 2021 12:42
To: planning_admin
Subject: FW: FW: P/2021/0289 - Bryn Hedd
Attachments: Bryn Hedd, Bwlchgwyn-03 Proposed Plan.pdf

Civ – 'drainage plan web' attached and 'additional info web' below

From: Spencer Cullis <ajones540@btinternet.com>
Sent: 21 June 2021 12:36 PM
To: Sharon Holman <Sharon.Holman@wrexham.gov.uk>
Subject: RE: FW: P/2021/0289 - Bryn Hedd

Hi Sharon,

The client has had a company to look at the new septic tank and they've confirmed that it should be sited where the existing one is (shown on the attached plan) and the discharge water should be located adjacent, i.e. on the feild to the left of the main entrance.

They have confirmed that the capacity will be 4800 litres and the daily flow rate will be 1050 litres.

A porosity test is being carried out on Wednesday so I can let you have the results this week.

Kind regards,

Spencer Cullis

CULLIS ARCHITECTURAL DESIGN

T 01978 264376

M 077914 80768

Rydym yn croesawu gohebiaeth yn Gymraeg. Byddwn yn ymateb i unrhyw ohebiaeth yn Gymraeg ac ni fydd hyn yn arwain at unrhyw oedi.

Ewch i weld - mi fedrwch chi dalu, rhoi gwybod, gwneud cais, dweud eich dweud, a dod o hyd i wybodaeth ar-lein yn www.wrecsam.gov.uk. Arbedwch bapur - meddylwch cyn argraffu!

Mae'r neges e-bost hon ac unrhyw atodiadau wedi eu bwriadu ar gyfer yr unigolyn neu'r sefydliad y'i cyfeirir atynt yn unig. Am yr amodau llawn ynglŷn â chynnwys a defnyddio'r neges e-bost hon, ac unrhyw atodiadau, cyfeiriwch at www.wrecsam.gov.uk/top_navigation/disclaimersw.htm

We welcome correspondence in Welsh. We will respond to any correspondence in Welsh and this will not lead to any delay.

Take a look - you can pay, report, request, have your say and find information online at www.wrexham.gov.uk. Save paper - think before you print!

This e-mail message and any attachments are intended solely for the individual or organisation to whom it is addressed. For full conditions in relation to content and use of this e-mail message and any attachments, please refer to www.wrexham.gov.uk/top_navigation/disclaimers.htm

Kind regards,
Spencer Cullis
CULLIS ARCHITECTURAL DESIGN
T 01978 264376
M 077914 80768