

Wrexham County Borough Council  
16, Lord Street  
Wrexham  
LL11 1LG

**Date: 12/05/2021**  
**Our Ref: PLA0056635**  
**Your Ref: P/2021/0344**

Dear Sir/Madam,

**Site: Land adj to Llwybr Y Garth, Yr Ochr, Llangollen.**  
**Development: Outline Application (All Matters Reserved) For 1 Dwelling.**

We refer to your planning consultation relating to the above site, and we can provide the following comments in respect to the proposed development.

'We can advise that Froncysyllte WwTW does not have a phosphate permit. This matter will need to be considered further by the local planning authority.'

As of 7th January 2019, this proposed development may be subject to Schedule 3 of the Flood and Water Management Act 2010. The development therefore may require approval of Sustainable Drainage Systems (SuDS) features, in accordance with the 'Statutory standards for sustainable drainage systems – designing, constructing, operating and maintaining surface water drainage systems'. It is therefore recommended that the developer engage in consultation with [Wrexham Council], as the determining SuDS Approval Body (SAB), in relation to their proposals for SuDS features. Please note, Dwr Cymru Welsh Water is a statutory consultee to the SAB application process and will provide comments to any SuDS proposals by response to SAB consultation.

The proposed development site is crossed by 150mm public sewer, please see copy of indicative public sewer record attached. No operational development is to take place within 3 metres either side of the centreline of the sewer. We request that prior to commencing any operational development the location of this asset is determined. If operational development is likely to commence within 3 metres either side of the centreline of the sewer please stop works and contact us.

Notwithstanding this, we would request that if you are minded to grant Planning Consent for the above development that the **Conditions and Advisory Notes** listed below are included within the consent to ensure no detriment to existing residents or the environment and to Dwr Cymru Welsh Water's assets.

### **Conditions**

No surface water and/or land drainage shall be allowed to connect directly or indirectly with the public sewerage network

Reason: To prevent hydraulic overloading of the public sewerage system, to protect the health and safety of existing residents and ensure no pollution of or detriment to the environment

### **Advisory Notes**

The proposed development site is crossed by public sewers with the approximate position being marked on the attached Statutory Public Sewer Record. The positions shall be accurately located, marked out on site before works commence and no operational development shall be carried out within a specified easement zone either side of the centreline of the public sewers. The applicant is advised to contact Welsh Water to discuss.

The applicant may need to apply to Dwr Cymru / Welsh Water for any connection to the public sewer under S106 of the Water Industry Act 1991. If the connection to the public sewer network is either via a lateral drain (i.e. a drain which extends beyond the connecting property boundary) or via a new sewer (i.e. serves more than one property), it is now a mandatory requirement to first enter into a Section 104 Adoption Agreement (Water Industry Act 1991). The design of the sewers and lateral drains must also conform to the Welsh Ministers Standards for Gravity Foul Sewers and Lateral Drains, and conform with the publication "Sewers for Adoption"- 7th Edition. Further information can be obtained via the Developer Services pages of [www.dwrcymru.com](http://www.dwrcymru.com)

The applicant is also advised that some public sewers and lateral drains may not be recorded on our maps of public sewers because they were originally privately owned and were transferred into public ownership by nature of the Water Industry (Schemes for Adoption of Private Sewers) Regulations 2011. The presence of such assets may affect the proposal. In order to assist us in dealing with the proposal the applicant may contact Dwr Cymru Welsh Water to establish the location and status of the apparatus. Under the Water Industry Act 1991 Dwr Cymru Welsh Water has rights of access to its apparatus at all times.

Our response is based on the information provided by your application. Should the proposal alter during the course of the application process we kindly request that we are re-consulted and reserve the right to make new representation.

If you have any queries please contact the undersigned on 0800 917 2652 or via email at [developer.services@dwrcymru.com](mailto:developer.services@dwrcymru.com)



Welsh Water is owned by Glas Cymru – a 'not-for-profit' company.  
Mae Dwr Cymru yn eiddo i Glas Cymru – cwmni 'nid-er-elw'.

We welcome correspondence in  
Welsh and English

Dŵr Cymru Cyf, a limited company registered in  
Wales no 2366777. Registered office: Pentwyn Road,  
Nelson, Treharris, Mid Glamorgan CF46 6LY

Rydym yn croesawu gohebiaeth yn y  
Gymraeg neu yn Saesneg

Dŵr Cymru Cyf, cwmni cyfyngedig wedi'i gofrestru yng  
Nghymru rhif 2366777. Swyddfa gofrestredig: Heol Pentwyn  
Nelson, Treharris, Morgannwg Ganol CF46 6LY.

Please quote our reference number in all communications and correspondence.

Yours faithfully,

**Rhodri Perry**  
**Development Control officer**  
**Developer Services**



Welsh Water is owned by Glas Cymru – a ‘not-for-profit’ company.  
Mae Dŵr Cymru yn eiddo i Glas Cymru – cwmni ‘nid-er-elw’.

We welcome correspondence in  
Welsh and English

Dŵr Cymru Cyf, a limited company registered in  
Wales no 2366777. Registered office: Pentwyn Road,  
Nelson, Treharris, Mid Glamorgan CF46 6LY

Rydym yn croesawu gohebiaeth yn y  
Gymraeg neu yn Saesneg

Dŵr Cymru Cyf, cwmni cyfyngedig wedi'i gofrestru yng  
Nghymru rhif 2366777. Swyddfa gofrestredig: Heol Pentwyn  
Nelson, Treharris, Morgannwg Ganol CF46 6LY.