

OFFICIAL



Network Rail
1st Floor
Bristol Temple Point
Bristol
BS1 6NL

My Ref: W/TP20/141
Your Ref: P/2020/0525

Date: 24 September 2020

TOWN AND COUNTRY PLANNING ACT 1990 (as amended)

APPLICATION NO: P/2020 /0525

PROPOSAL: ERECTION OF PLANT COMPOUND AND INSTALLATION OF EXTERNAL PLANT

LOCATION: LIDL SUPERMARKET HOPE STREET GWERSYLLT WREXHAM

Dear Sir/Madam,

Thank you for your email dated **4 September 2020** together with the opportunity to comment on this proposal.

Network Rail has no objection in principle to the above proposal but due to the proposal being next to Network Rail land and our infrastructure and to ensure that no part of the development adversely impacts the safety, operation and integrity of the operational railway we have included asset protection comments which the applicant is strongly recommended to action should the proposal be granted planning permission.

SAFETY

Any works on this land will need to be undertaken following engagement with Asset Protection to determine the interface with Network Rail assets, buried or otherwise and by entering into a Basic Asset Protection Agreement, if required, with a minimum of 3months notice before works start. Initially the outside party should contact assetprotectionwales@networkrail.co.uk .

DRAINAGE

Soakaways / attenuation ponds / septic tanks etc, as a means of storm/surface water disposal must not be constructed near/within 5 metres of Network Rail's boundary or at any point which could adversely affect the stability of Network Rail's property/infrastructure. Storm/surface water must not be discharged onto Network Rail's property or into Network Rail's culverts or drains. Network Rail's drainage system(s) are not to be compromised by any work(s). Suitable drainage or other works must be provided and maintained by the Developer to prevent surface water flows or run-off onto Network Rail's property / infrastructure. Ground levels – if altered, to be such that water flows away from the railway. Drainage is not to show up on Buried service checks.

SITE LAYOUT

It is recommended that all buildings be situated at least 2 metres from the boundary fence, to allow construction and any future maintenance work to be carried out without involving entry onto Network Rail's infrastructure. Where trees exist on Network Rail land the design of foundations close to the boundary must take into account the effects of root penetration in accordance with the Building Research Establishment's guidelines.

FENCING

Network Rail's existing fencing / wall must not be removed or damaged and at no point either during construction or after works are completed on site should the foundations of the fencing or wall or any embankment therein be damaged, undermined or compromised in any way. Any vegetation on Network Rail land and within Network Rail's boundary must also not be disturbed.

Yours Sincerely,

Grace Lewis

Town Planning Technician Wales and Western
Network Rail

Temple Point, Redcliffe Way, Bristol, BS1 6NL

E grace.lewis@networkrail.co.uk

www.networkrail.co.uk/property

The content of this email (and any attachment) is confidential. It may also be legally privileged or otherwise protected from disclosure.

This email should not be used by anyone who is not an original intended recipient, nor may it be copied or disclosed to anyone who is not an original intended recipient.

If you have received this email by mistake please notify us by emailing the sender, and then delete the email and any copies from your system.

Liability cannot be accepted for statements made which are clearly the sender's own and not made on behalf of Network Rail.

Network Rail Infrastructure Limited registered in England and Wales No. 2904587,
registered office Network Rail, 2nd Floor, One Eversholt Street, London, NW1 2DN

