

Cerys Jones

From: Jason Russell
Sent: 23 December 2020 13:43
To: Cerys Jones
Subject: RE: AMEND PLNS LET BLANK - App ref P/2020/0606 - BIG GREEN FARM
ELLESMERE LANE PENLEY WREXHAM

Hi Cerys,

Thank you for the recent consultation on the above application for discharge of condition.

Prior to discharge of this condition I would request that this information is provided.

- Operation and Maintenance plan for Permeable Paving, is this to be adopted by HA, if not please provide details of private management company.
- What is the discharge point of drainage? Permeable paving calculations state it is attenuation, therefore, please confirm on drainage drawing where outflow discharges to?

Kind regards
Jason Russell
Peiriannydd / Engineer