

MEMORANDUM


From: Chief Officer, Environment & Technical **To:** Chief Officer Planning & Regulatory
Our Ref: ET/DC/P/2020/0318 **Your Ref:** SW/P/2020/0318
Date: 16th February 2021

Town and Country Planning Act 1990

Section 78 Appeal @ Elm Villa, Wrexham Road, Marchwiell, Wrexham.

I refer to your consultation / email dated 15/02/2021 in respect of the above.

I am satisfied with the previous response made to this application (copy attached) and wish to inform you that I have no further comments to add.



Chief Officer, Environment & Technical

MEMORANDUM

From: Chief Officer Environment & Technical **To:** Chief Officer Planning & Regulatory
Our Ref: ET/DC/P/2020/0318 **Your Ref:** MP/P/2020/0318
Date: 6th August 2020

TOWN AND COUNTRY PLANNING ACT 1990

TOWN AND COUNTRY (GENERAL DEVELOPMENT PROCEDURE) ORDER 1995

Location: O. S Grid Ref: 352 481 Elm Villa, Wrexham Road, Marchwiell, Wrexham.

Development: New dwelling and alteration to access.

I refer to your email / consultation dated 27/07/2020 including site layout plan (Drg. No. EV-TACP-PS-00-DR-A-702) in respect of the above.

Access

The proposed 4.8m wide access appears acceptable.

There is an existing telegraph pole located on the southern corner of the existing access. This will need to be re-located in order to construct the suggested access. **A suitable condition will be required to ensure this is carried out.** The existing dropped kerb serving the site will need to be extended in the southerly direction.

Parking & Turning Provision

I understand that the existing dwelling is 3 bedroomed and the proposed dwelling is 2 bedroomed.

LPGN 16 normally requires a maximum of 2 spaces per 2 bed dwelling and 3 spaces per 3 bed dwelling. Given the busy nature of the A525 fronting the property, I would recommend that parking provision at the site is provided in accordance with maximum standards.

The existing property has at least 6 parking spaces at present (garages excluded).

The submitted layout plan indicates 2 parking spaces each for both Elm Villa and for the proposed dwelling plus a communal turning facility. The existing dwelling previously provided at least 6 parking spaces. I would recommend that a 3rd parking space is provided for the existing property as previously requested.

I would recommend that the applicant submits a revised layout plan indicating / annotating the above details.

Notes to Applicant

- FOOTWAY CROSSING LICENCE

A licence should be obtained (as required by section 184 of the Highways Act 1980) from the Highway Authority in order to lower the kerbline and cross the footpath at the new access position (widened access). Further guidance can be obtained from the Highways Department of Wrexham County Borough Council on telephone

Supplementary Notes

The applicant's attention should be drawn to item nos. 1, 2, 3, 4 & 5 of the supplementary notes.



Chief Officer Environment & Technical