

MEMORANDUM



From: Ian Jones Public Protection
Service Manager

To: David Williams Planning
Control Manager

Our Ref:

Your Ref: P/2020 /0387

Date: 26-08-2020

Town and Country Planning Act 1990

Town and Country Planning (General Development Procedure) Order 1996

Re: P/2020 /0387, UNIT 2 AND 3 LORD STREET WREXHAM

NEWIDIADAU I DDRYCHIADAU I ADLEOLI DRYSAU MYNEDIAD / ALTERATIONS TO ELEVATIONS TO RELOCATE ENTRANCE DOORS

Environmental Protection

A22NA – CONSTRUCTION / DEMOLITION SITE NOISE

All works in relation to the implementation of this permission, including deliveries to and /or leaving the site, should be undertaken only between the hours of 07.30 to 18.00 Monday to Friday, 08.00 to 14.00 on a Saturday, and at no time on a Sunday or a Bank Holiday. Outside these times, any works which are audible beyond the site boundary have the potential to cause unreasonable disturbance to neighbouring premises.

The applicant is advised that the Council has the option to control construction noise by serving a Control of Pollution Act 1974, Section 60 Notice where deemed necessary, and failure to comply with such a Notice can result in prosecution.

The applicant is further advised that any complaints received relating to noise of any type from the development may also be investigated using the Council's Standardised Procedure for Dealing with Noise Nuisance Complaints. This is done under the Statutory Nuisance provisions provided within the Environmental Protection Act 1990, and legal action may be taken where appropriate.

The applicant must adhere to the times given above wherever possible. If, however, there are urgent or unavoidable circumstances requiring work outside of the specified times, permission to proceed may be sought by contacting Environmental Health & Housing Standards at healthandhousing@wrexham.gov.uk or 01978 292 040. Please use the same contact details for any other enquiries regarding construction / demolition site noise.

.....
Head of Planning and Regulatory