

Maes Y Ffynnon,
Penrhosgarnedd,
Bangor,
Gwynedd
LL572DW

Wrexham County Borough Council,
The Guildhall,
Wrexham,
LL11 1AY

ebost/email:
northplanning@cyfoethnaturiolcymru.gov.uk

29/03/2021

Dear Mr Greenland,

PROPOSAL: Erection of new building for storage purposes

LOCATION: Bryn Y Pys Home Farm, Wrexham Road, Overton, Wrexham

Thank you for consulting Cyfoeth Naturiol Cymru / Natural Resources Wales about the above, which we received on 11/03/2021.

We have significant concerns with the proposed development as submitted. We recommend you should only grant planning permission if you include the following documents within the condition identifying approved plans and documents on the decision notice:

- Susan Worsfold. Ecological Appraisal and Impact Assessment – Bryn y Pys Home Farm. 3rd February 2021.
- Susan Worsfold. Additional Ecological Mitigation Measures Report - Bryn y Pys Home Farm Report. 3rd February 2021.

Protected Species

We note that the bat reports submitted in support of the above application ('Susan Worsfold. Ecological Appraisal and Impact Assessment at Bryn y Pys Home Farm. 3rd February 2021' and 'Susan Worsfold. Additional Ecological Mitigation Measures Report – Bryn y Pys Home Farm Report. 3rd February 2021') have identified that bats are not present at the application site, but that it may be used by foraging and commuting bats. From the information submitted, we consider that the proposed development represents a lower risk for bats, as defined in our guidance document 'Natural Resources Wales Approach to Bats and Planning (2015)'. Bats and their breeding and resting places are protected under the Conservation of Habitats and Species Regulations 2017.

As this is a lower risk case for bats, we consider that the development is not likely to be detrimental to the maintenance of the population of the species concerned at a favourable conservation status in its natural range.

Furthermore, we advise that the proposed development is not likely to harm or disturb the bats or their breeding sites and resting places at this site, provided the avoidance measures described in the bat reports are implemented.

The reports must be included in the 'approved list of plans / documents' condition within the decision notice should consent for the project be granted.

Protected Sites

We note the application site is within the catchment of the River Dee and Bala Lake Special Area of Conservation (SAC). As you are aware, on the 21st January 2021, we published an evidence package outlining phosphate levels for all river SACs across Wales. As part of this package, we issued a [Planning Position Statement](#), in which we advised that any proposed development that might increase the amount of phosphate within a river SAC catchment could lead to damaging effects to the SAC. Therefore, such proposals should be screened through a Habitats Regulations Assessment (HRA), to determine whether they are likely to have a significant effect on the SAC.

However, the application as submitted is unlikely to increase the amount or concentration of phosphate discharged directly or indirectly into the catchment. Therefore, we are satisfied that the proposal is not likely to have a significant effect on the River Dee and Bala Lake SAC.

Other Matters

Our comments above only relate specifically to matters included on our checklist, *Development Planning Advisory Service: Consultation Topics* (September 2018), which is published on our [website](#). We have not considered potential effects on other matters and do not rule out the potential for the proposed development to affect other interests.

We advise the applicant that, in addition to planning permission, it is their responsibility to ensure they secure all other permits/consents/licences relevant to their development. Please refer to our [website](#) for further details.

Advice for the Developer

Environmental Management:

All works at the site must be carried out in accordance with PPG6: 'Working at construction and demolition sites' which are available on the following website: <http://www.netregs.org.uk/environmental-topics/pollution-prevention-guidelines-ppgs-and-replacement-series/guidance-for-pollution-prevention-gpps-full-list/>

The activity of importing waste into the site for use as, for example hardcore, must be registered with Natural Resources Wales as an exempt/permittable activity under the Environmental Permitting Regulations 2016. The developer should contact Natural Resources Wales to discuss the necessity for an exemption/permit for any material imported to and exported from the site.

If during construction/excavation works any contaminated material is revealed, then the movement of such material either on or off site should be done in consultation with Natural Resources Wales. Any waste excavation material or building waste generated in the course of the development must be disposed of satisfactorily and in accordance with Section 34 of the Environmental Protection Act 1990. Carriers transporting waste from the site must be registered waste carriers and movement of any Hazardous Waste from the site must be accompanied by Hazardous waste consignment notes.

If you have any queries on the above, please do not hesitate to contact us.

Yours faithfully,

Joy Evans

Cynghorydd - Cynllunio Datblygu / Advisor - Development Planning
Cyfoeth Naturiol Cymru / Natural Resources Wales