



**Cyfoeth
Naturiol
Cymru
Natural
Resources
Wales**

Ein cyf/Our ref: CAS-123419-T1S5
Eich cyf/Your ref: P/2020/0480

Maes Y Ffynnon,
Penrhosgarnedd,
Bangor,
Gwynedd
LL572DW

Wrexham County Borough Council,
The Guildhall,
Wrexham,
LL11 1AY

ebost/email:
northplanning@cyfoethnaturiolcymru.gov.uk

01/09/2020

Dear Sir/Madam,

PROPOSAL: CONSTRUCTION OF NEW VEHICULAR ACCESS

LOCATION: FARTHING WOOD 4, THE NURSERY, OVERTON ROAD, BANGOR ON DEE, WREXHAM

Thank you for consulting Cyfoeth Naturiol Cymru / Natural Resources Wales about the above, which we received on 26/08/2020.

We have no objection to the proposed development as submitted and provide the following advice.

Flood Risk

Our Flood Risk Map confirms the site includes a small area of Zone C1 of the Development Advice Map (DAM) contained in TAN15 and the 1% (1 in 100 year) annual probability fluvial flood outline.

Given the location of flood risk shown to be affecting the application site (and in the absence of a flood consequences assessment) we consider the proposals could be acceptable, subject to the developer being made aware of the potential flood risks to these areas.

Other Matters

Our comments above only relate specifically to matters included on our checklist, *Development Planning Advisory Service: Consultation Topics* (September 2018), which is published on our [website](#). We have not considered potential effects on other matters and do not rule out the potential for the proposed development to affect other interests.

We advise the applicant that, in addition to planning permission, it is their responsibility to ensure they secure all other permits/consents/licences relevant to their development. Please refer to our [website](#) for further details.

Advice for the Developer

Works near Watercourse

Due to the proximity of the site to watercourses, all works at the site must be carried out in accordance with GPP5 and PPG6: 'Works in, near or over watercourses' and 'Working at construction and demolition sites' which are available on the following website: <http://www.netregs.org.uk/environmental-topics/pollution-prevention-guidelines-ppgs-and-replacement-series/guidance-for-pollution-prevention-gpps-full-list/>

Pollution Prevention

During the construction phase you should take any precaution to prevent contamination of surface water drains and local watercourses. Oils and chemicals should be stored in bunded areas and spill kits should be readily available in case of accidental spillages.

For further guidance please refer to GPP 5 and PPG 6 at the following link:

<http://www.netregs.org.uk/environmental-topics/pollution-prevention-guidelines-ppgs-and-replacement-series/guidance-for-pollution-prevention-gpps-full-list/>

Environmental Management

All works at the site must be carried out in accordance with PPG6: 'Working at construction and demolition sites' which are available on the following website:

<http://www.netregs.org.uk/environmental-topics/pollution-prevention-guidelines-ppgs-and-replacement-series/guidance-for-pollution-prevention-gpps-full-list/>

The activity of importing waste into the site for use as, for example hardcore, must be registered with Natural Resources Wales as an exempt/permittable activity under the Environmental Permitting Regulations 2016. The developer should contact Natural Resources Wales to discuss the necessity for an exemption/permit for any material imported to and exported from the site.

If during construction/excavation works any contaminated material is revealed, then the movement of such material either on or off site should be done in consultation with Natural Resources Wales. Any waste excavation material or building waste generated in the course of the development must be disposed of satisfactorily and in accordance with Section 34 of the Environmental Protection Act 1990. Carriers transporting waste from the site must be registered waste carriers and movement of any Hazardous Waste from the site must be accompanied by Hazardous waste consignment notes.

If you have any queries on the above, please do not hesitate to contact us.

Yours faithfully

Tristan Williams

Cynghorydd - Cynllunio Datblygu / Advisor - Development Planning
Cyfoeth Naturiol Cymru / Natural Resources Wales