

Maes Y Ffynnon,
Penrhosgarnedd,
Bangor,
Gwynedd
LL572DW

Wrexham County Borough Council,
The Guildhall,
Wrexham,
LL11 1AY

ebost/email:
northplanning@cyfoethnaturiolcymru.gov.uk

01/03/2021

Annwyl Syr/Madam / Dear Sir/Madam,

**BWRIAD / PROPOSAL: CARAFAN BRESWYL (YN OL DREMIOL) /RESIDENTIAL
CARAVAN (IN RETROSPECT)**

**LLEOLIAD / LOCATION: PENYLLAN FARM, WREXHAM ROAD, MARCHWIEL,
WREXHAM**

Thank you for consulting Cyfoeth Naturiol Cymru / Natural Resources Wales about the above, which we received on 02/02/2021

We have significant concerns with the proposed development as submitted. We recommend you should only grant planning permission if the following requirement is met. Otherwise, we would object to this planning application.

Requirement (Foul drainage) site to be connected to the mains sewerage system or satisfactory evidence to be provided to demonstrate that it is not reasonable to connect to mains.

Foul Drainage

We note that the intention is to dispose of foul drainage to a private sewerage system, i.e. a septic tank. According to our records, the proposed development is located within a publicly sewered area. The installation of private sewage treatment facilities within publicly sewered areas is not normally considered environmentally acceptable because of the greater risk of failures leading to pollution of the water environment compared to public sewerage systems.

Section 6.6.21 of Planning Policy Wales states 'Any development discharging domestic sewage should connect to the foul sewer where it is reasonable to do so. Development proposing the use of non-mains drainage schemes will only be considered acceptable where connection to the main sewer is not feasible...'

Government guidance on private sewerage in Welsh Government Circular 008/2018 stresses that the first presumption must be to provide a system of foul drainage discharging into a public sewer. Only where having taken into account the cost and/or practicability it can be shown to the satisfaction of the local planning authority that connection to a public sewer is not feasible, should non-mains foul sewage disposal solutions be considered.

We therefore require the Applicant to either amend their proposals to ensure that the foul drainage is connected to the mains sewerage system or provide detailed evidence to demonstrate that it is not reasonable to connect.

The Applicant should thoroughly investigate the possibility of connecting to the foul sewer by taking the following steps:

- Formally approach the sewerage undertaker regarding a connection under Section 106 or a requisition under Section 98 of the Water Industry Act (WIA) 1991.
- Serve notice for connection under Section 106 of the WIA 1991 if the sewerage undertaker has refused connection.
- Provide details of the reasons given by the sewerage undertaker if it has refused connection under section 98 or section 106 of the WIA 1991 and confirmation that they have appealed against this decision.
- Demonstrate that it is not reasonable to connect to the public foul sewer.
- Where it is not reasonable to connect to the public foul sewer, demonstrate that they have considered requesting that the sewerage undertaker adopt their proposed system.

The Applicant should be aware that should a connection to the mains sewer not be feasible, they will also need to demonstrate that the proposal would not pose an unacceptable risk to the water environment. Welsh Government Circular 008/2018 advises that a full and detailed consideration be given to the environmental criteria listed under paragraph 2.6 of the Circular, in order to justify the use of private sewerage.

The Applicant should also be aware that should a connection to the mains sewer not be feasible, they will need to apply for an environmental permit or register an exemption with us. As stated above, we expect developers discharging domestic sewage to connect to the public foul sewer where it is reasonable to do so. We will not normally grant a discharge permit for a private sewage treatment system where it is reasonable to connect to the public foul sewer. We also expect discharges of trade effluent to connect to the public foul sewer where it is reasonable to do so and subject to the sewerage undertaker granting a trade effluent consent or entering into a trade effluent agreement.

Septic tanks and small sewage treatment works may be registered as exempt from the requirement to obtain an environmental permit if certain criteria are met. Please note, should a permit be required, further information may be required as part of that application and the

Applicant is therefore advised to hold pre-application discussions with our Permitting Team on 0300 065 3000, at the earliest opportunity, to try to ensure that there is no conflict between any planning permission granted and the permit requirements. It is important to note that a grant of planning permission does not guarantee that a permit will be granted, should a proposal be deemed to be unacceptable (either because of environmental risk or because upon further investigation, a connection to mains sewer was feasible). The Applicant should ensure that they have all the required permissions, consents, permits and any other approvals in place prior to commencement of works on the site.

More information, including a step by step guide to registering and the relevant application forms are available on our [website](#) . Where private sewage treatment/disposal facilities are utilised, they must be installed and maintained in accordance with British Standard 6297 and Approved Document H of the Building Regulations. We also refer the Applicant to Guidance for Pollution Prevention 4 on the [NetRegs website](#), which provides further information.

Please note, a lack of capacity, or plans to improve capacity in the sewer, is not a valid reason for a sewerage undertaker to refuse connection under Section 106 of the Water Industry Act 1991 and we may refuse to issue an environmental permit or exemption for private treatment facilities in such circumstances.

Protected Sites

We note the application site is within the catchment of the River Dee and Bala Lake Special Area of Conservation (SAC). As you are aware, on the 21st January 2021, we published an evidence package outlining phosphate levels for all river SACs across Wales. As part of this package, we issued a [planning position statement](#), in which we confirmed that any proposed development that might increase the amount of phosphate within a river SAC catchment could lead to damaging effects to the SAC. Therefore, such proposals should be screened through a Habitats Regulations Assessment (HRA), to determine whether they are likely to have a significant effect on the site's qualifying features. We also issued [Interim Planning Advice](#), which gives specific advice in respect of foul drainage arrangements for new developments.

We note from the information submitted that the proposal intends to connect to private foul drainage. As explained above (Requirement 1, Foul Drainage section), we advise that the proposal should connect to the mains sewer.

The development has the potential to increase the volume or concentration of wastewater and associated phosphate levels being discharged within the catchment of the SAC. Should you conclude that the proposed development is likely to have a significant effect on the SAC, we look forward to being consulted on your appropriate assessment under Regulation 63 of the Conservation of Habitats and Species Regulations 2017 (as amended).

Other Matters

Our comments above only relate specifically to matters included on our checklist, *Development Planning Advisory Service: Consultation Topics* (September 2018), which is

