







PADSTONE TO BE BEDDED ON CLASS II MORTAR.
 PADSTONE STRAPPED TO MASONRY WITH 2 NUMBER PROPRIETARY GALVANISED STRAPS
 BEAM FIXED TO PADSTONE WITH 2 no M8 BOLTS

NOTE:
 THE FINAL FOUNDATION FORMATION DEPTH IS TO BE AGREED ON SITE WITH THE BUILDING CONTROL INSPECTOR. THE PRESENCE AND TYPE OF ANY TREES COMBINED WITH CLAY SOILS (IF PRESENT) MAY NECESSITATE FOUNDATION DEPTHS IN EXCESS OF THOSE SHOWN



SECTION THROUGH SLEEPER WALL



SECTION THROUGH REAR WALL

Notes:

1. THE COPYRIGHT OF THIS DRAWING IS VESTED IN ALIGN ENGINEERING LTD AND IT MAY NOT BE REPRODUCED IN WHOLE OR PART OR USED FOR THE MANUFACTURE OF ANY ARTICLE WITHOUT THE EXPRESS PERMISSION OF THE COPYRIGHT HOLDERS.
 2. WORK TO FIGURED DIMENSIONS ONLY.
 3. THIS DRAWING IS TO BE READ IN CONJUNCTION WITH ALL RELEVANT ARCHITECTS, SERVICE ENGINEERS AND ALIGN ENGINEERING LTD DRAWINGS AND SPECIFICATIONS.

FOR PLANS REFER TO DRAWING SE01

FOR NOTES REFER TO DRAWING SE03

B	REVISED TO ARCHITECT'S CHANGES	YH	11.09.2020
A	FIRST ISSUE.	YH	02.10.2019
REV:	DESCRIPTION:	BY:	DATE:
STATUS: TENDER			

Struktura Engineering Services
 Civil and Structural Consultants

CLIENT: IRWIN MITCHELL

ARCHITECT: EDWARD ARCHITECTURE

SITE: HOLT HILL
 HOLT, WREXHAM

TITLE: STRUCTURAL DETAILS

SCALE AT A3: 1:20 1:10	DATE: 24.09.2019	DRAWN: YH	CHECKED: KH
PROJECT NO: 19169	DRAWING NO: SE02	REVISION: B	