

Maes Y Ffynnon,
Penrhosgarnedd,
Bangor,
Gwynedd
LL572DW

Wrexham County Borough Council,
The Guildhall,
Wrexham,
LL11 1AY

ebost/email:
northplanning@cyfoethnaturiolcymru.gov.uk

04/02/2021

Dear Mr Greenland,

PROPOSAL: Construction of agricultural worker's dwelling and garage

LOCATION: Coxwood Farm, Cox Lane, Rossett, Wrexham

Thank you for consulting Cyfoeth Naturiol Cymru / Natural Resources Wales about the above, which we received on 22/01/2021.

We have no objection to the proposed development as submitted and provide the following advice.

Groundwater Protection

We note that the proposed development site is partially within Special Protection Zone (SPZ) 3 for groundwater, in this case within 50m of a spring. No indication has been given on the plans as to the position of the proposed private foul water treatment plant and its discharge field/ soakaway.

We would advise that both treatment plant and drainage site must be placed outside the 50m buffer zone around the spring.

The applicant is referred to further guidance in the Advice for the Developer section below.

Protected Species

We note that there is no information about protected species with the application and, therefore, are assuming that your Authority has screened the application and concluded that there is not a reasonable likelihood of protected species being present.

Other Matters

Our comments above only relate specifically to matters included on our checklist, *Development Planning Advisory Service: Consultation Topics* (September 2018), which is published on our [website](#). We have not considered potential effects on other matters and do not rule out the potential for the proposed development to affect other interests.

We advise the applicant that, in addition to planning permission, it is their responsibility to ensure they secure all other permits/consents/licences relevant to their development. Please refer to our [website](#) for further details.

Advice for the Developer

Foul Drainage:

The Applicant should note, it is a legal requirement to apply for an environmental permit or register an exemption with us. Septic tanks and small sewage treatment works may be registered as exempt from the requirement to obtain an environmental permit if certain criteria are met. Please note, should a permit be required, further information may be required as part of that application and the Applicant is therefore advised to hold pre-application discussions with our Permitting Team on 0300 065 3000, at the earliest opportunity, to try to ensure that there is no conflict between any planning permission granted and the permit requirements.

If the Applicant already holds an exemption / permit, they should check whether the proposed increase in flows would require a further application to be made for a new / varied permit. It is important to note that a grant of planning permission does not guarantee that a permit will be granted, should a proposal be deemed to be unacceptable (either because of environmental risk or because upon further investigation, a connection to mains sewer was feasible). The Applicant should ensure that they have all the required permissions, consents, permits and any other approvals in place prior to commencement of works on the site.

More information, including a step by step guide to registering and the relevant application forms are available on our [website](#). Where private sewage treatment/disposal facilities are utilised, they must be installed and maintained in accordance with British Standard 6297 and Approved Document H of the Building Regulations. We also refer the Applicant to Guidance for Pollution Prevention 4 on the [NetRegs website](#), which provides further information.

Environmental Management:

Due to the proximity of the site to watercourses, all works at the site must be carried out in accordance with GPP5 and PPG6: 'Works in, near or over watercourses' and 'Working at construction and demolition sites' which are available on the following website: <https://www.netregs.org.uk/environmental-topics/guidance-for-pollution-prevention-gpp-documents/guidance-for-pollution-prevention-gpps-full-list/>

If you have any queries on the above, please do not hesitate to contact us.

Yours faithfully,

Joy Evans

Cynghorydd - Cynllunio Datblygu / Advisor - Development Planning
Cyfoeth Naturiol Cymru / Natural Resources Wales