

Cerys Jones

From: Jason Russell
Sent: 03 September 2020 14:24
To: Cerys Jones
Subject: CONSULTATION - GENERAL LETTER - App ref P/2020/0456

Hi Cerys,

Thank you for the recent consultation on the above application for outline permission.

**AMNEWID OFFER GWAITH TRIN ELIFIANT / REPLACEMENT EFFLUENT TREATMENT PLANT
EQUIPMENT ROWAN FOODS LTD OSCAR MAYER LTD ASH ROAD SOUTH WREXHAM
INDUSTRIAL ESTATE WREXHAM**

The site is located in DAM Zone A as defined within TAN15. However, adjacent land to the east of the site is located within in DAM Zone C2 as defined within TAN15. The replacement effluent treatment plant is located in an area at high risk of surface water flooding on the site as depicted on NRW surface water flood risk map. As a minimum I would strongly recommend the applicant incorporate flood resistant and resilient construction techniques into the works if permission were granted.

SuDS Approving Body Approval Requirement

As you will be aware, from the 7th of January 2019 any new development of more than one dwelling or that involves construction work of more than 100m2 is required to obtain approval from the SuDS Approving Body (SAB) prior to the commencement of those construction works. No formal application for SAB approval or request for pre application SAB advice has been received to date. It is unclear from the information provided if SAB approval will be required in this instance, however, due to the scale and nature of the development it is likely that a compliant sustainable surface water management scheme can be delivered.

If the application were to be approved, I would request the following note to applicant be included on any permissions to re emphasis the requirement to obtain full SAB approval prior to the commencement of any construction works on site:

Note to Applicant – SAB Approval Required

Following the commencement of Schedule 3 of the Flood and Water Management Act, the works as proposed are required to obtain approval from the SuDS Approving Body (SAB) prior to commencement of those construction works. Further details of the SAB, the new national standards, the pre-application advice service and the application for approval process can be found on the Wrexham CBC's SAB webpage:

https://www.wrexham.gov.uk/english/planning_portal/sab/sab.htm or by contacting the SAB Team directly at SAB@wrexham.gov.uk.

If you have any questions on the above please let me know.

Kind regards

Jason Russell
Engineer / Peiriannydd



Environment and Planning Department Abbey Road South Wrexham Industrial Estate Wrexham LL13 9PW

Adran Amgylchedd a Chynllunio De Ffordd yr Abaty Ystâd Ddiwydiannol Wrecsam Wrecsam LL13 9PW

 wrexham.gov.uk | wreccsam.gov.uk
 twitter.com/wrexhamcbc | twitter.com/cbswreccsam
 facebook.com/wrexhamcouncil | facebook.com/cyngorwreccsam 📞