

MEMORANDUM



From: Ian Jones Public Protection
Service Manager

To: David Williams Planning
Control Manager

Our Ref:

Your Ref: P/2020/0449

Date: 08-09-2020

Town and Country Planning Act 1990

Town and Country Planning (General Development Procedure) Order 1996

Re: P/2020/0449, 23 CHESTER ROAD GRESFORD WREXHAM

FFLIW ECHDYNNU (YN ÔL DREMIOL) / EXTRACTION FLUE (IN RETROSPECT)

ZP04 - AIR HANDLING / EXTRACTION PLANT BS4142 ASSESSMENT

The rating level of any noise generated by air handling plant associated with the development shall not exceed the pre-existing background level at any time. The noise levels shall be determined at nearby noise sensitive premises, and measurements and assessment shall be made in accordance with BS4142:2014 Methods for rating and assessing industrial and commercial sound.

.....
Head of Planning and Regulatory