

MEMORANDUM



From: Ian Jones Public Protection
Service Manager

To: David Williams Planning
Control Manager

Our Ref:

Your Ref: P/2020/0599

Date: 20-10-2020

Town and Country Planning Act 1990

Town and Country Planning (General Development Procedure) Order 1996

Re: P/2020/0599, LLOYDS ANIMAL FEEDS BRIDGE ROAD NORTH WREXHAM INDUSTRIAL ESTATE WREXHAM

CODI ADEILAD AR GYFER DEUNYDDIAU CRAI A PHEIRIANNAU CYSYLLTIEDIG / ERECTION OF BUILDING FOR RAW MATERIALS AND ASSOCIATED PLANT

A23N - BURNING OF WASTE ADVICE

Burning of waste generated from construction activities is not considered to be an appropriate method of disposal and action may be taken as follows:

Under the Environmental Protection Act 1990 anyone found disposing of construction site waste by burning is likely to be in breach of their duty of care with regard to waste disposal;

Under the same Act an abatement notice may be served where smoke is judged to be causing a nuisance to neighbouring properties. Failure to comply with the requirements of such a notice can result in prosecution;

Under the Clean Air Act 1993 it is an offence for a commercial activity to burn anything that gives rise to dark smoke.

To prevent offences under the above named Acts there should be no bonfires on the site, to include the prohibition of the burning of cleared vegetation. The applicant should contact the Council's Planning & Regulatory Department on 01978 292 040 for further advice and information.

ZP05 - NOISE GENERATION - BS4142 REQUIRED

The rating level of any noise generated by reason of this development shall not exceed the pre-existing background level at any time. The noise levels shall be determined at nearby noise sensitive premises, and measurements and assessment shall be made in accordance with BS4142:2014 Methods for rating and assessing industrial and commercial sound.

.....
Head of Planning and Regulatory