

MEMORANDUM



From: Stacey Inglis
Contaminated Land Officer

To: David Williams
Planning Control Manager

Our Ref: P/2020/0421

Your Ref: P/2020/0421

Date: 20 August 2020

No. of 2
Pages:

TOWN AND COUNTRY PLANNING ACT 1990

RE: P/2020/0421 – GREDINGTON ARMS HOLT RAOD LLANYPWLL WREXHAM

CONVERSION OF PUBLIC HOUSE AND OUTBUILDING INTO THREE DWELLINGS INCLUDING EXTENSIONS AND EXTERNAL ALTERATIONS

- **Recommended Contamination Conditions**

It is noted that the proposed development is within 250 metres of a former landfill site known as 'Llanypwll Landfill'. In light of this, it will be necessary to condition any future consent so as to ensure that any potential contamination migration issues are adequately dealt with. I would recommend that the following conditions and note to applicant be applied to any future consent that may be granted.

ZP01A GAS PROTECTION MEASURES

No part of the development shall commence until a scheme to deal with potential contamination at the site has been submitted to and approved in writing by the Local Planning Authority. This scheme shall include a phased investigation approach to identify the extent of contamination and any measures required to remediate the site, including post-development monitoring. Alternatively, gas protection measures should be installed in all new buildings. A methodology of these works (including specification details, design plans, installation, inspection and validation details etc...) should be submitted in writing to the Council for approval prior to any works commencing on site.

WCBC02 :: ZP02A - Verification Report - Contaminated Land

Each part of the site subject to the remediation under the scheme(s) approved as part of condition @@ shall not be occupied/used until a Validation Report has been completed in respect of that part of the site and submitted to and approved in writing by the Local Planning Authority.

WCBC21 :: A11NA - SITE CONTAMINATION

Further advice on compliance with condition no. @@ may be obtained by contacting the Council's Contaminated Land Team on 01978 298870 or contaminatedland@wrexham.gov.uk. Should the investigation identify contamination issues that may affect receptors other than the site users e.g. groundwater, then it is recommended that these works are also addressed in consultation with the Council's Environmental Protection Team prior to commencement of works on site.

Should you have any queries regarding the above then please contact me on Ext. 8773.



PP.

.....
Dave Sharp
Building Control Lead