



EXTERIOR LIGHTING NOTES:

SYMBOL

QUANTITY

15

PROPOSED EXTERIOR LIGHT UNIT

ASD EXTERIOR LED HALF LANTERN MOUNTED AT 3m HEIGHT WITH PIR SENSOR - 4000K 0.28KLm OUTPUT

LUX CONTOUR LINES:

SYMBOL	DESCRIPTION
0.20 LUX CONTOUR LINE	0.20 LUX CONTOUR LINE
0.50 LUX CONTOUR LINE	0.50 LUX CONTOUR LINE
1.00 LUX CONTOUR LINE	1.00 LUX CONTOUR LINE
2.00 LUX CONTOUR LINE	2.00 LUX CONTOUR LINE
5.00 LUX CONTOUR LINE	5.00 LUX CONTOUR LINE
10.00 LUX CONTOUR LINE	10.00 LUX CONTOUR LINE

NOTES:

1. THE PROPOSALS HAVE BEEN DESIGNED FOR WAYMARKING PURPOSES ONLY.

2. THIS DESIGN HAS BEEN PREPARED IN ACCORDANCE WITH HEA-HEMSA GUIDANCE NOTE - CDM2015 REGULATIONS, ISSUE 1.1, DATED 09/04/15

2.1. PROCEDURE 2 - OUTLINE DESIGN - BASED ON INFORMATION PROVIDED BY THE CLIENT.

3. ALL APPARATUS TO BE:

3.1. INSTALLED AND TESTED IN COMPLIANCE WITH BS7671 LATEST EDITION.

3.2. NUMBERED / LABELED AS AGREED WITH SITE MANAGEMENT TEAM.

3.3. NEW AT THE TIME OF INSTALLATION AND SUPPORTED BY RELEVANT MANUFACTURERS GUARANTEES AND DATA SHEETS.

4. ISO-LUX CONTOUR LINES SHOWN ARE INDICATIVE.

5. CONSTRUCTION SHOULD NOT BE STARTED UNTIL PLANNING PERMISSION HAS BEEN GRANTED BY THE LOCAL AUTHORITY. ANY WORKS TAKING PLACE PRIOR TO APPROVAL SHALL BE AT THE DEVELOPERS RISK.

A

REVISED DETAILS

PW

05/05/20

REV:

DESCRIPTION:

BY:

DATE:

STATUS: FOR APPROVAL

Williams Lighting Consultants Ltd.

info@wclighting.co.uk

www.wclighting.co.uk

01234 630039

WLC

CLIENT:

LIBERTY GROUP

626 ECCLES NEW ROAD

SALFORD

M5 5SJ

SITE:

NANT SILYN

WREXHAM

TITLE:

EXTERIOR LIGHTING

CONTOUR PLAN

SCALE AT A2:

1:250

DATE:

29/04/20

DRAWN:

PW

CHECKED:

LD

PROJECT NO:

WLC344

DRAWING NO:

WLC344-1300-001

REVISION:

A