

MEMORANDUM



From: Angela Guy
Contaminated Land Officer

To: Simon Greenland
Planning Officer

Our Ref: P/2020/0158

Your Ref: P/2020/0158

Date: 07 April 2020

**No. of
Pages:** 1

P/2020/0158 – YSGOL BRO ALUN, DELAMERE AVENUE, GWERSYLLT

Apologies I wasn't aware that there were plans to review in addition to the report that I referred to in my email dated 16 March 2020 regarding the discharge of condition 5.

Having now reviewed the plans, I note the drawing ref: YBA-LAW_X-X-DR—A-300003 rev T00 refers to a Visqueen Gas Barrier 1400 gauge membrane, with a Visqueen geotex protection blanket and lap tape. In addition there is reference to a venting and collection system with details shown on another plan (not provided), the reference is hard to read but could be PD2009149131.

These measures appear to be consistent with those provided in the original school building although the plan showing the gas collection system and the specification of the membrane itself should be provided and clarification on who will validate the installation of the measures too.

A handwritten signature in black ink, appearing to read 'Angela Guy', written in a cursive style.

Angela Guy
Contaminated Land Officer