

**AnnS Jones**

---

**From:** Matthew Phillips  
**Sent:** 12 March 2020 14:17  
**To:** planning\_admin  
**Subject:** FW: CONSULTATION - GENERAL LETTER - App ref P/2020/0155

Please add as flood officer comments

---

**From:** flooding  
**Sent:** 11 March 2020 10:02  
**To:** Matthew Phillips  
**Cc:** flooding  
**Subject:** RE: CONSULTATION - GENERAL LETTER - App ref P/2020/0155

Matthew,

Thank you for the recent consultation on the above application for full planning permission.

The site is located in DAM Zone A as defined within TAN15.

**SuDS Approving Body Approval Requirement**

As you will be aware, from the 7th of January 2019 any new development of more than one dwelling or that involves construction work of more than 100m2 is required to obtain approval from the SuDS Approving Body (SAB) prior to the commencement of those construction works. No formal application for SAB approval or request for pre application SAB advice has been received to date. In the absence of the full consideration of the requirements of the National Standards for SuDS, and requirements of Schedule 3 of the Flood and Water Management Act, it has not been demonstrated that a compliant sustainable surface water management scheme can be delivered for the site. It is likely that this requirement will have implications for the proposed development, particularly in relation to the layout. In some instances it may not be possible to identify a scheme that can successfully comply with the national standards.

Prior to the determination of the application, and as a matter of urgency, I would strongly advise the applicant give full consideration to the implications that compliance to the National SuDS standards may have for the development and revise proposals accordingly whilst also pursuing SAB approval. While it is possible to seek planning permission in isolation of seeking SAB approval, there is a significant risk in pursuing such an approach. The earlier it can be determined that the proposals are compliant with the new standards the less chance of delay, wasted effort and costs for all parties involved. If no additional information is submitted prior to determination I would request the application be refused as it has not been demonstrated that surface water can be sustainably managed over the lifetime of the development.

If you have any questions on the above please let me know.

Many thanks

Neil

-----Original Message-----

From: Susan Davies <[Susan.Davies@wrexham.gov.uk](mailto:Susan.Davies@wrexham.gov.uk)>  
Sent: 10 March 2020 16:06  
To: flooding <[flooding@wrexham.gov.uk](mailto:flooding@wrexham.gov.uk)>  
Subject: CONSULTATION - GENERAL LETTER - App ref P/2020/0155

Please find attached document