

Wrexham County Council
16 Lord Street
Wrexham
LL11 1LG

Date: 27/12/2019
Our Ref: PLA0046641
Your Ref: P/2019/0897

Dear Sir

Site: Site at Eversley Court Minera, Wrexham

**Development: Approval of details reserved by conditions under planning reference; P/2019/0355;
Condition 6, 9 (drainage), 12, 13, 14, 15, 20, 25 & 26.**

SEWERAGE

We refer to the above application regarding the information submitted pursuant to the discharge of condition no. 9 attached to the above planning permission

We have reviewed drawing reference Drainage Layout, with foul water discharging to the public sewerage system and surface water draining through SuDS features that discharge to a culvert.

On the basis that no surface water will be discharging directly/indirectly to the public sewer Welsh Water have no objection to the discharge of condition no.9 attached to the above planning consent.

Our response is based on the information provided by your application. Should the proposal alter during the course of the application process we kindly request that we are re-consulted and reserve the right to make new representation.

If you have any queries please contact the undersigned on 0800 917 2652 or via email at developer.services@dwrcymru.com

Please quote our reference number in all communications and correspondence.

Yours faithfully,

Rhodri Perry
Development Control Officer
Developer Services