

05/09/2019

Dear Sir/Madam,

PROPOSAL: OUTLINE PLANNING APPLICATION TO ERECT 1 NO. FOUR BED DETACHED HOUSE WITH DOUBLE GARAGE.

LOCATION: GWYLFA, RUTHIN ROAD, BWLCHGWYN, WREXHAM

Thank you for consulting Cyfoeth Naturiol Cymru / Natural Resources Wales about the above, which was received on 20/08/2019.

We have no objection to the proposed development, but wish to make the following comments:-

Foul Drainage:

No information has been provided regarding the disposal of foul waters from the proposed development. We refer you to WG Circular 008/2018 on the use of private sewerage in new developments, and specifically paragraphs 2.3-2.5, which stress the first presumption must be to provide a system of foul drainage discharging into a public sewer. We advise you the proposed development is in a publicly sewered area.

Please consult us again if foul sewage from the proposed development is to be disposed of by a private sewerage system.

Please do not hesitate to contact us if you require further information or clarification of any of the above.

Our comments above only relate specifically to matters that are listed in our 'Consultation Topics' document (September 2018) which is published on our website: (<https://cdn.naturalresources.wales/media/686847/dpas-consultation-topics-august-2018-eng.pdf?mode=pad&rnd=131819256840000000>). We have not considered potential effects on other matters and do not rule out the potential for the

proposed development to affect other interests, including environmental interests of local importance.

Advice for the Developer:

Environmental Management:

All works at the site must be carried out in accordance with PPG6: 'Working at construction and demolition sites' which are available on the following website:

<http://www.netregs.org.uk/environmental-topics/pollution-prevention-guidelines-ppgs-and-replacement-series/guidance-for-pollution-prevention-gpps-full-list/>

The activity of importing waste into the site for use as, for example hardcore, must be registered with Natural Resources Wales as an exempt/permittable activity under the Environmental Permitting Regulations 2016. The developer should contact Natural Resources Wales to discuss the necessity for an exemption/permit for any material imported to and exported from the site.

If during construction/excavation works any contaminated material is revealed, then the movement of such material either on or off site should be done in consultation with Natural Resources Wales. Any waste excavation material or building waste generated in the course of the development must be disposed of satisfactorily and in accordance with Section 34 of the Environmental Protection Act 1990. Carriers transporting waste from the site must be registered waste carriers and movement of any Hazardous Waste from the site must be accompanied by Hazardous waste consignment notes.

The applicant should be advised that, in addition to planning permission, it is their responsibility to ensure that they secure all other permits/consents relevant to their development.

Pollution Prevention:

During the construction phase you should take any precaution to prevent contamination of surface water drains and local watercourses. Oils and chemicals should be stored in bunded areas and spill kits should be readily available in case of accidental spillages.

For further guidance please refer to GPP 5 and PPG 6 at the following link:

<http://www.netregs.org.uk/environmental-topics/pollution-prevention-guidelines-ppgs-and-replacement-series/guidance-for-pollution-prevention-gpps-full-list/>

The applicant should be advised that, in addition to planning permission, it is their responsibility to ensure that they secure all other permits/consents relevant to their development.

Yn gywir / Yours faithfully,

Garmon Lewis

Mr G Lewis
Development Planning Assistant
Development Planning Advisory Service