

AnnS Jones

From: Sharon Holman
Sent: 30 September 2019 13:08
To: planning_admin
Subject: FW: P/2019/0734

Civ – pp resp

From: Nick Minshall <Nick.Minshall@wrexham.gov.uk>
Sent: 30 September 2019 11:27
To: Sharon Holman <Sharon.Holman@wrexham.gov.uk>
Subject: RE: P/2019/0734

Hi Sharon

A statement regarding road sweeping is not a DMS. The applicant is required to provide details of dust mitigation measures to be employed throughout the construction phase of the development. This should include raw materials handling, stockpiling, plant to be used on site, appropriate water suppression as necessary for operations likely to generate dust, site & highway sweeping/damping down as required, some form of visual dust assessments and recording, etc., etc.

Regards Nick

From: Sharon Holman
Sent: 30 September 2019 10:51
To: Nick Minshall
Subject: RE: P/2019/0734

Hi Nick,

There is a section on page 10 at 4.6.

Sharon

From: Nick Minshall <Nick.Minshall@wrexham.gov.uk>
Sent: 30 September 2019 10:15
To: Sharon Holman <Sharon.Holman@wrexham.gov.uk>
Subject: P/2019/0734

Hi Sharon

I've looked through the documentation attached to the above application and can't see a dust management plan.

There is a Construction Management Plan, but it doesn't detail dust prevention measures.

Regards Nick