

Cerys Jones

From: Mared Rees-Jones
Sent: 31 May 2019 12:12
To: planning_admin
Subject: FW: P/2019/0302 - The Stables Caravan Park, Southsea

Please add consultation response to file

From: Neil Taunt
Sent: 07 May 2019 08:35
To: Mared Rees-Jones
Subject: RE: P/2019/0302 - The Stables Caravan Park, Southsea

Hi Mared,

I have reviewed the submitted information. There is very limited information included in support of the discharge of the surface water condition. Prior to being able to comment further the following information is required:

- Infiltration test results carried out in accordance with BRE365.
- Calculations to demonstrate the sizing of any associated soakaways based on contributing impermeable areas
- Details of future management and maintenance of the proposed system.

Many thanks

Neil

From: Mared Rees-Jones
Sent: 24 April 2019 14:09
To: Neil Taunt
Subject: P/2019/0302 - The Stables Caravan Park, Southsea

Hi Neil

A discharge of conditions application has been submitted for the above site – they are seeking to discharge condition 13 attached to P/2018/0004.

Can you let me know what your comments are – standard 21 day consultation period.

Thanks

Mared

Mared Rees-Jones MRTPI
Swyddog Cynllunio/Area Planning Officer



 01978 298776
 Wrexham County Borough Council, 16 Lord Street, Wrexham LL11 1LG
 Cyngor Bwrdeistref Sirol Wrecsam, 16 Stryt yr Arglwydd, Wrecsam LL11 1LG

 wrexham.gov.uk | wreccsam.gov.uk
 twitter.com/wrexhamcbc | twitter.com/cbswreccsam
 facebook.com/wrexhamcouncil | facebook.com/cyngorwreccsam