

Karen Thorley

From: Peter Douthwaite <Peter.Douthwaite@wrexham.gov.uk>
Sent: 16 April 2019 13:25
To: Karen Thorley
Subject: RE: Blast Road, Brymbo

WCBC HIGHWAY RESPONSE

1. Visibility splays can now be reduced to 2.4m x 43m as the road is now within a 30mph limit; the original 70m splays were pre Manual for Streets 2. If grassed service strips are being reduced to 600mm then all services will need to be constructed within the 2m wide footways.
3. All grassed areas including service strips will need to be maintained by a private management company.
4. Dwg 18303/SK03 suggests that you are proposing a soakaway that serves private housing within the adopted highway. We will not accept private soakaway drainage within the adopted highway.
5. The private soakaway to the rear of plots 7,8,& 9 appears to be partially within the adopted highway. This is unacceptable.
6. The roof water and private land from plots 1 to 6 appear to be draining into the surface water system. The highway authority do not accept private drainage in the highway surface water system.
7. I would suggest that you need to come up with a new surface water drainage strategy and need also to consider the latest SAB legislation - I'd recommend you discuss this with our Water Management Officer Neil Taunt.
8. The Swept Path Analysis are very difficult to make out on an A3 plan. Please forward either an A1 plan of a cad drawing for us to print off at the correct size. The radius of the bends look like they will create difficulty for the refuse wagon to manoeuvre through - is it feasible to put widen the carriageway by 1m through the bends?
9. The turning head doesn't appear to be the correct size - see attached plan with latest design standard.
10. There is only 1 parking space provided for plot 2?

Regards

Pete Douthwaite
Senior Development Control Engineer Uwch Beiriannydd Rheoli Datblygu
01978 729689

Cyngor Bwrdeistref Sirol Wrecsam, Adran Amgylchedd a Chynllunio, De Ffordd yr Abaty, Ystad Ddiwydiannol Wrecsam, Wrecsam LL13 9PW

Wrexham County Borough Council, Environment and Planning Department, Abbey Road South, Wrexham Industrial Estate, Wrexham LL13 9PW

wrecsam.gov.uk | wrexham.gov.uk

twitter.com/cbswrecsam | twitter.com/wrexhamcbc

facebook.com/cyngorwrecsam | facebook.com/wrexhamcouncil

-----Original Message-----

From: Karen Thorley [mailto:karen.thorley@brenigconstruction.co.uk]
Sent: 15 April 2019 17:14
To: Peter Douthwaite
Cc: Bleddyn Jones; Bryn Roberts
Subject: Blast Road, Brymbo

Good afternoon Peter,

Thank you for your email.

We will be completing the Consultation report by close of play on Wednesday, 17th April, so would very much welcome your response by then.

Should you wish to discuss the scheme, please contact me tomorrow on 01492 514934.

Kind regards,

Karen Thorley

<html><body>

Rydym yn croesawu gohebiaeth yn Gymraeg. Byddwn yn ymateb i unrhyw ohebiaeth yn Gymraeg ac ni fydd hyn yn arwain at unrhyw oedi.

Ewch i weld - mi fedrwch chi dalu, rhoi gwybod, gwneud cais, dweud eich dweud, a dod o hyd i wybodaeth ar-lein yn www.wreccsam.gov.uk. Arbedwch bapur - meddyliwch cyn argraffu!

Mae'r neges e-bost hon ac unrhyw atodiadau wedi eu bwriadu ar gyfer yr unigolyn neu'r sefydliad y?i cyfeirir atynt yn unig. Am yr amodau llawn yngl?n ? chynnwys a defnyddio?r neges e-bost hon, ac unrhyw atodiadau, cyfeiriwch at www.wreccsam.gov.uk/top_navigation/disclaimersw.htm

We welcome correspondence in Welsh. We will respond to any correspondence in Welsh and this will not lead to any delay.

Take a look - you can pay, report, request, have your say and find information online at www.wrexham.gov.uk. Save paper - think before you print!

This e-mail message and any attachments are intended solely for the individual or organisation to whom it is addressed. For full conditions in relation to content and use of this e-mail message and any attachments, please refer to www.wrexham.gov.uk/top_navigation/disclaimers.htm

</body>

</html>