

P/2019/0246 (4946/19)

Contaminated Land

During the development of the houses (P/2003/0676), the site investigations undertaken at the time found ground gas risk sufficient to warrant gas protection measures; therefore it is prudent to ensure the gas protection measures are put in place within any extensions to the properties.

ZP01A	GAS PROTECTION MEASURES <u>(Use ZP02 and A11NA)</u>
053R	Gas protection measures should be installed in all new buildings. A methodology of these works (including specification details, design plans, installation, inspection and validation details etc...) should be submitted in writing to the Council for approval prior to any works commencing on site.

Helen Bradshawe
05 April 2019