

From:

Philip Forster
19 July 2019 08:07
planning_admin
FW: Suggested noise condition for P/2018 /1087



Public protection response for P/2018/1087

From: Toby Zorn

Sent: 18 July 2019 14:59

To: David Williams; Philip Forster

Subject: Suggested noise condition for P/2018 /1087

Hello David

Please see the below suggested noise condition as discussed: -

An acoustic assessment showing that the rating level of any noise generated by the operation of the proposed development (including vehicles, machinery and air handling / conditioning plant, associated with the whole of the development) shall not exceed the pre-existing background level by more than 5dB(A) at any time, as measured at the nearest noise sensitive premises.

I would also recommend that a further sentence be added to the above statement to ensure that any future use must comply with the 5dB(A) condition.

If you need any more detail please give me a shout.

Best regards

Toby Zorn

Swyddog Arbenigol (Iechyd yr Amgylchedd a Tai)
Specialist Officer (Environmental Health and Housing)

☎ 01978 297 426 / 07800 688 705

✉ Cyngor Bwrdeistref Sirol Wrecsam, 16 Stryt yr Arglwydd, Wrecsam LL11 1LG

✉ Wrexham County Borough Council, 16 Lord Street, Wrexham LL11 1LG

🌐 wrecsam.gov.uk | wrexham.gov.uk

🐦 twitter.com/cbcwrecsam | twitter.com/wrexhamcbc

📘 facebook.com/cyngor_wrecsam | facebook.com/wrexhamcouncil

Mae'n bosib y bydd y wybodaeth a gasglwyd gennyf yn cael ei rannu gydag adrannau neu sefydliadau eraill er mwyn i ni allu darparu gwasanaeth i chi. Mae rhagor o fanylion ar gael ar yr adran Hysbysiad Preifatrwydd ar wefan y Cyngor

The information I have collected may be shared with other departments or organisations in order that we can provide a service to you. Further details are available on the Privacy Notice section of the Council's website