

Susan Davies

From: Sharon Holman
Sent: 25 March 2019 13:05
To: planning_admin
Subject: FW: P/2019/0151 The Towers Nursery, Llangollen Road, Trevor

civ- pp resp

From: Angela Guy
Sent: 25 March 2019 12:56
To: 'Craig Baugh'
Cc: Sharon Holman
Subject: RE: P/2019/0151 The Towers Nursery, Llangollen Road, Trevor

Hello Craig

The Contaminated Land Team advised of potential risks to the above proposed development due to the proximity to a former landfill site. Our records indicate the site is approximately 35m away, I note the desk study report prepared by Geotechnics refers to the same landfill as being c. 125m away. Potential gas risks from this former landfill is the primary concern for this team as we're not aware of any other potentially contaminative concerns present. Therefore should any gas protection measures be incorporated into the development so far then these may offer sufficient protection, provided they can be verified as being present and details of what they comprise be provided. I note that some radon protection may have been provided and would recommend further details of this and any other measures be forwarded so these can be considered further.

Regards Angela

Ms Angela Guy BSc (Hons) MSc

Contaminated Land Officer

Swyddog Tir wedi ei Halogi



01978 298771
Environment and Planning Department, 16 Lord Street, Wrexham LL11 1LG
Adran Amgylchedd a Chynllunio, 16 Stryt yr Arglwydd, Wrecsam LL11 1LG
wrexham.gov.uk | wrecsam.gov.uk
twitter.com/wrexhamcbc | twitter.com/cbswrecsam
facebook.com/wrexhamcouncil | facebook.com/cyngorwrecsam

From: Craig Baugh [mailto:craig@cbarchitecturaldesign.co.uk]
Sent: 22 March 2019 08:56
To: Angela Guy
Subject: Fw: P/2019/0151 The Towers Nursery, Llangollen Road, Trevor

Hello Angela,

Have received the following response from Sharon Holman regarding the above application;

Land Contamination

Please submit a detailed scheme of the gas protection measures that been installed in the foundation of the building. If radon protection was required then please also submit details of this. Evidence that shows that these measures have been installed should also be provided.

Was there anything specific regarding the gas protection and was it relating to the foundations or the ground floor slab in general?

Radon protection is only required in residential dwellings but at a minimum the contractor would have installed a 1200 gauge DPM lapped to the inner leaf DPC and cavity tray so it would by default provide 'basic' radon protection.

I have tried to contact the geotechnical engineer who produced the report but he is away at the moment.

Thanks in advance.

Regards

Craig Baugh

CB Architectural Design



: (07833) 029535



: info@cbarchitecturaldesign.co.uk

The information contained in or attached to this email is intended only for the use of the individual or entity to which it is addressed. If you are not the intended recipient, or a person responsible for delivering it to the intended recipient, you are not authorised to and must not disclose, copy, distribute or retain this message or any part of it. It may contain information which is confidential and/or covered by legal, professional or other privilege, or other rules or laws with similar effect in jurisdictions outside England and Wales.

From: [Sharon Holman](#)

Sent: Friday, March 22, 2019 8:46 AM

To: 'Craig Baugh'

Subject: RE: P/2019/0151 The Towers Nursery, Llangollen Road, Trevor

Hi Craig,

Can I direct you to the contaminated land officer? Her name is Angela Guy and her email is: Angela.guy@wrexham.gov.uk tel no. 01978 298771.

Kind regards

Sharon

From: Craig Baugh [mailto:craig@cbarchitecturaldesign.co.uk]
Sent: 22 March 2019 08:39
To: Sharon Holman
Subject: Re: P/2019/0151 The Towers Nursery, Llangollen Road, Trevor

Thank you Sharon,

Was there anything specific regarding the gas protection and was it relating to the foundations or the ground floor slab in general?

Radon protection is only required in residential dwellings but at a minimum the contractor would have installed a 1200 gauge DPM lapped to the inner leaf DPC and cavity tray so it would by default provide 'basic' radon protection.

I have tried to contact the geotechnical engineer but he is away at the moment.

Thanks in advance.

Regards

Craig Baugh
CB Architectural Design



: (07833) 029535

: info@cbarchitecturaldesign.co.uk

The information contained in or attached to this email is intended only for the use of the individual or entity to which it is addressed. If you are not the intended recipient, or a person responsible for delivering it to the intended recipient, you are not authorised to and must not disclose, copy, distribute or retain this message or any part of it. It may contain information which is confidential and/or covered by legal, professional or other privilege, or other rules or laws with similar effect in jurisdictions outside England and Wales.

From: [Sharon Holman](#)
Sent: Friday, March 22, 2019 8:02 AM
To: 'Craig Baugh'
Subject: RE: P/2019/0151 The Towers Nursery, Llangollen Road, Trevor

Thanks Craig, I will send this across to the contamination land team.

Regards

Sharon

From: Craig Baugh [mailto:craig@cbarchitecturaldesign.co.uk]
Sent: 21 March 2019 18:40
To: Sharon Holman
Subject: Re: P/2019/0151 The Towers Nursery, Llangollen Road, Trevor

Hi Sharon,

Have received this final land contamination report for your information.

Regards

Craig Baugh

CB Architectural Design



: (07833) 029535



: info@cbarchitecturaldesign.co.uk

The information contained in or attached to this email is intended only for the use of the individual or entity to which it is addressed. If you are not the intended recipient, or a person responsible for delivering it to the intended recipient, you are not authorised to and must not disclose, copy, distribute or retain this message or any part of it. It may contain information which is confidential and/or covered by legal, professional or other privilege, or other rules or laws with similar effect in jurisdictions outside England and Wales.

From: [Sharon Holman](#)

Sent: Thursday, March 21, 2019 2:04 PM

To: info@cbarchitecturaldesign.co.uk

Subject: P/2019/0151 The Towers Nursery, Llangollen Road, Trevor

Dear Craig,

Drainage

The site is located in DAM Zone X as defined within TAN15. In the absence of the full consideration of the requirements of the National Standards for SuDS, and requirements of Schedule 3 of the Flood and Water Management Act, it has not been demonstrated that a compliant sustainable surface water management scheme can be delivered for the site. The application indicates that the proposed works will include the resurfacing of the existing car parking area. The application would indicate that surface waters will be managed by soakaway. However, no information has been submitted to indicate that ground conditions are suitable for soakaways and this appears to conflict between plans (drainage and landscaping). Please submit a soakaway drainage scheme.

Land Contamination

Please submit a detailed scheme of the gas protection measures that been installed in the foundation of the building. If radon protection was required then please also submit details of this. Evidence that shows that these measures have been installed should also be provided.

Landscaping Plan

Please amend to show the proposed parking spaces delineated with brick setts to accord with plan ref: 2015 0890 Rev A.

Parking Management Plan

Can you look again at the plan and amend it to ensure that it refers only to the application site. It currently refers to pub and lodge car park.

Many thanks

Sharon

Sharon Holman

Development Control Planning Officer/ Swyddog Cynllunio Rheoli Datblygu



☎ 01978 298779

✉ Wrexham County Borough Council, 16 Lord Street, Wrexham,
LL11 1LG

✉ Cyngor Bwrdeistref Sirol Wreccsam, 16 Stryt yr Arglwydd, Wreccsam,
LL11 1LG

🌐 wrexham.gov.uk | wreccsam.gov.uk

🐦 twitter.com/wrexhamcbc | twitter.com/cbswreccsam

📘 facebook.com/wrexhamcouncil | facebook.com/cyngorwreccsam

Rydym yn croesawu gohebiaeth yn Gymraeg. Byddwn yn ymateb i unrhyw ohebiaeth yn Gymraeg ac ni fydd hyn yn arwain at unrhyw oedi.

Ewch i weld - mi fedrwch chi dalu, rhoi gwybod, gwneud cais, dweud eich dweud, a dod o hyd i wybodaeth ar-lein yn www.wreccsam.gov.uk. Arbedwch bapur - meddyliwch cyn argraffu!

Mae'r neges e-bost hon ac unrhyw atodiadau wedi eu bwriadu ar gyfer yr unigolyn neu'r sefydliad y?i cyfeirir atynt yn unig. Am yr amodau llawn yngl?n ? chynnwys a defnyddio'r neges e-bost hon, ac unrhyw atodiadau, cyfeiriwch at www.wreccsam.gov.uk/top_navigation/disclaimersw.htm

We welcome correspondence in Welsh. We will respond to any correspondence in Welsh and this will not lead to any delay.

Take a look - you can pay, report, request, have your say and find information online at www.wrexham.gov.uk. Save paper - think before you print!

This e-mail message and any attachments are intended solely for the individual or organisation to whom it is addressed. For full conditions in relation to content and use of this e-mail message and any attachments, please refer to www.wrexham.gov.uk/top_navigation/disclaimers.htm

Rydym yn croesawu gohebiaeth yn Gymraeg. Byddwn yn ymateb i unrhyw ohebiaeth yn Gymraeg ac ni fydd hyn yn arwain at unrhyw oedi.

Ewch i weld - mi fedrwch chi dalu, rhoi gwybod, gwneud cais, dweud eich dweud, a dod o hyd i wybodaeth ar-lein yn www.wreccsam.gov.uk. Arbedwch bapur - meddylwch cyn argraffu!

Mae'r neges e-bost hon ac unrhyw atodiadau wedi eu bwriadu ar gyfer yr unigolyn neu'r sefydliad y'i cyfeirir atynt yn unig. Am yr amodau llawn ynglŷn â chynnwys a defnyddio'r neges e-bost hon, ac unrhyw atodiadau, cyfeiriwch at www.wreccsam.gov.uk/top_navigation/disclaimersw.htm

We welcome correspondence in Welsh. We will respond to any correspondence in Welsh and this will not lead to any delay.

Take a look - you can pay, report, request, have your say and find information online at www.wrexham.gov.uk. Save paper - think before you print!

This e-mail message and any attachments are intended solely for the individual or organisation to whom it is addressed. For full conditions in relation to content and use of this e-mail message and any attachments, please refer to www.wrexham.gov.uk/top_navigation/disclaimers.htm

Rydym yn croesawu gohebiaeth yn Gymraeg. Byddwn yn ymateb i unrhyw ohebiaeth yn Gymraeg ac ni fydd hyn yn arwain at unrhyw oedi.

Ewch i weld - mi fedrwch chi dalu, rhoi gwybod, gwneud cais, dweud eich dweud, a dod o hyd i wybodaeth ar-lein yn www.wreccsam.gov.uk. Arbedwch bapur - meddylwch cyn argraffu!

Mae'r neges e-bost hon ac unrhyw atodiadau wedi eu bwriadu ar gyfer yr unigolyn neu'r sefydliad y'i cyfeirir atynt yn unig. Am yr amodau llawn ynglŷn â chynnwys a defnyddio'r neges e-bost hon, ac unrhyw atodiadau, cyfeiriwch at www.wreccsam.gov.uk/top_navigation/disclaimersw.htm

We welcome correspondence in Welsh. We will respond to any correspondence in Welsh and this will not lead to any delay.

Take a look - you can pay, report, request, have your say and find information online at www.wrexham.gov.uk. Save paper - think before you print!

This e-mail message and any attachments are intended solely for the individual or organisation to whom it is addressed. For full conditions in relation to content and use of this e-mail message and any attachments, please refer to www.wrexham.gov.uk/top_navigation/disclaimers.htm