

MEMORANDUM



From: Ian Jones Public Protection
Service Manager

To: David Williams Planning
Control Manager

Our Ref:

Your Ref: P/2019/0505

Date: 20-08-2019

Town and Country Planning Act 1990

Town and Country Planning (General Development Procedure) Order 1996

Re: P/2019/0505, KRONOSPAN LTD HOLYHEAD ROAD CHIRK WREXHAM

DEVELOPMENT OF A BUILDING CONTAINING 2 NO. GAS ENGINES EACH WITH A MAXIMUM ELECTRICITY GENERATING CAPACITY OF 9.73 MW, 2 NO. STEAM BOILERS, ROOF MOUNTED COOLERS, WALKWAY BETWEEN AN ADJACENT BUILDING AND THE PROPOSED BUILDING, EXHAUST GAS OFFTAKE PIPES AND STEAM PIPES FROM THE GAS ENGINE BUILDING AND CARBON CATALYST ABATEMENT SYSTEM

Contaminated Land - No Comments

No Comments

Environmental Protection - No Comments

The air quality report entitled "Kronospan Air Quality Analysis" dated 27/06/19, concluded that:

This analysis has shown that there would be no material change in the air quality impact from the current operations on site, especially as these CHP gas engines would replace the operation of the two Gas Turbines on site.

The conclusion is accepted.

.....
Head of Planning and Environment