

MEMORANDUM



From: Ian Jones Public Protection
Service Manager

To: David Williams Planning
Control Manager

Our Ref:

Your Ref: P/2019/0559

Date: 31-07-2019

Town and Country Planning Act 1990

Town and Country Planning (General Development Procedure) Order 1996

Re: P/2019/0559, THE TURF HOTEL MOLD ROAD WREXHAM

SITING AND USE OF MOBILE CATERING UNIT (4.9 X 2.1M) FOR THE SALE OF HOT AND COLD FOOD TO MEMBERS OF THE PUBLIC DURING THE HOURS OF 08.00 AM - 1.30 PM MONDAY TO SATURDAY

Contaminated Land - No Comments

No Comments

ZP05 - NOISE GENERATION - BS4142 REQUIRED

If the mobile unit requires a generator:

The rating level of any noise generated by reason of this development shall not exceed the pre-existing background level by more than 5dB(A) at any time. The noise levels shall be determined at nearby noise sensitive premises, and measurements and assessment shall be made in accordance with BS4142:2014 Methods for rating and assessing industrial and commercial sound.

.....
Head of Planning and Environment