

Susan Davies

From: Sharon Holman
Sent: 10 June 2019 12:16
To: planning_admin
Subject: FW: P/2019/0402

Civ – flood officer resp

From: Neil Taunt
Sent: 10 June 2019 10:46
To: Sharon Holman
Subject: P/2019/0402

Hi Sharon,

Thanks you for the recent consultation on the above discharge of condition.

I am aware that there is a discrepancy in the calculations used to size the soakaways proposed for both private surface and highway drainage. Prior to commenting further I would request revised calculations are submitted based on the latest BRE365 methodology. In addition, details of how the responsibility for the future management and maintenance of any shared private soakaways (eg. SA10 and SA4) will be secured is required.

If you have any questions please let me know.

Many thanks

Neil

Neil Taunt MCIWEM C.WEM CEnv CSci

Uwch Swyddog Rheoli Llifogydd / Senior Flood Management Officer



 01978 729734 / 07808 787632

 Cyngor Bwrdeistref Sirol Wreccsam, Adran Amgylchedd a Thechnegol, De Ffordd yr Abaty, Ystad Ddiwydiannol Wreccsam, Wreccsam LL13 9PW

 Wrexham County Borough Council, Environment & Technical Department, Abbey Road South, Wrexham Industrial Estate, Wrexham LL13 9PW

 wreccsam.gov.uk | wrexham.gov.uk

 twitter.com/cbswreccsam | twitter.com/wrexhamcbc

 facebook.com/cyngorwreccsam | facebook.com/wrexhamcouncil