

MEMORANDUM

From:	Service Manager Environment	To:	Head of Community Well-being and Development
Our Ref:	P/2018/1047	Your Ref:	P/2018/1047
Date:	25 June 2019		

TOWN AND COUNTRY PLANNING ACT 1990
TOWN AND COUNTRY (GENERAL DEVELOPMENT PROCEDURE) ORDER 1995

Location: O. S Grid Ref: 2890 4590 Land off Bryn Glas, Rhosllanerchrugog

Development: Demolition of existing property and erection of 1 no. dwelling and associated access.

I refer to your consultation dated 18 June 2019 in respect of the above.

The development site is at the end of a cul de sac on an unclassified highway that is subject to a 30 mph speed limit although vehicular speed is considered to be no more than 20mph due to the geometry of the road.

The road is generally 5m wide and serves approximately 37 existing properties. The existing turning head at the end of the cul de sac adequately caters for general vehicular use.

Given the width of the road and the small increase in traffic generation I do not anticipate that this having a detrimental impact on the highway.

The proposed road extension will be of adequate width to serve the dwelling; this road will remain in private ownership and will not be adopted by the Council. Adequate parking is provided for the proposed dwelling.

The new access benefits from a turning facility at the southern end of the road.

I recommend any permission include the following conditions:

ZJ017 038R	VISIBILITY SPLAYS (NEARSIDE) on to Bryn Glas Prior to first use of the development hereby approved the vehicular access shall provide visibility splays of 2.4 metres x 25 metres to the north and 2.4 metres x 15 metres to the west measured to the nearside edge of the adjoining highway. Within these splays there shall be no obstruction in excess of 1 metre in height above the level of the adjoining highway. The
-----------------------	--

splays shall thereafter be permanently retained clear of any such obstruction to visibility.

NONSTDC SUBMISSION OF FURTHER DETAILS

026R

E06N

E07N

No part of the development shall commence until a scheme detailing the construction of the following has been submitted to and approved in writing by the Local Planning Authority:

- Layout, design, drainage and construction of the proposed private driveway

The scheme as is approved shall be fully implemented prior to first use of the development.

ZJ22

035R

PARKING AND MANOEUVRING TO BE KEPT CLEAR

The vehicular parking and turning areas as shown on the approved drawing shall be fully laid out, surfaced and drained prior to first use of the development. These areas shall thereafter be permanently retained and kept free of any obstruction, and made available solely for the parking and turning of vehicles at all times.

NONSTDC

PRIVATE ROAD WIDTH

039R


The private road hereby approved shall be a minimum width of 4.8metres.

ZJ46

026R

NO PRIVATE SURFACE WATER RUN OFF

No private surface water run off shall be permitted to flow from the development site onto the adjoining highway. An Aco drain or similar shall be provided across the approved access to intercept any such run off prior to first use of the development.



Service Manager Environment

mv