

Susan Davies

From: Matthew Phillips
Sent: 10 June 2019 12:46
To: planning_admin
Subject: FW: P/2019/0253 - Gwersyllt Newsagents

Please add as Public Protection response

From: Nick Minshall
Sent: 07 June 2019 15:52
To: Matthew Phillips
Subject: RE: P/2019/0253 - Gwersyllt Newsagents

Hello Matthew

The proposed 2D podded silencer fitted in accordance with the recommendations contained in the Conclusions section of the AB Acoustics Report should achieve the requirements of the noise condition.

Regards Nick

From: Matthew Phillips
Sent: 07 June 2019 15:34
To: Nick Minshall
Subject: FW: P/2019/0253 - Gwersyllt Newsagents

Nick,

Please see attached. Can I have some further comments on this please?

Thanks

Matthew

From: Steve Eltham [mailto:steven@blueprintarchitectural.com]
Sent: 07 June 2019 11:32
To: Matthew Phillips
Subject: Re: P/2019/0253 - Gwersyllt Newsagents

Hi Matthew,

Please find attached a new noise report in relation to the above application.

I trust the attach now satisfies the condition?

Kind regards

Steven Eltham
Architectural Technician
For Blueprint Architectural Services

Tel: 01978 356500
steven@blueprintarchitectural.com

From: Matthew Phillips

Sent: Tuesday, May 7, 2019 4:31 PM
To: Steve Eltham
Subject: FW: P/2019/0253 - Gwersyllt Newsagents

Steve,

Please see below.

Regards

Matthew Phillips

Planning Control Lead/Arweinydd Rheoli Cynllunio
Environment and Planning/Amgylchedd a Chynllunio
Wrexham County Borough Council/Cyngor Bwrdeistref Sirol Wrecsam
Telephone/Ffôn: 01978 298780

From: Nick Minshall
Sent: 07 May 2019 15:21
To: Matthew Phillips
Subject: RE: P/2019/0253 - Gwersyllt Newsagents

Hello Matthew

The noise information submitted doesn't satisfy Condition 3 of the Planning Inspectorate's Decision Document.

The applicant is required to carry out a BS4142:2014 noise assessment to determine the noise rating level relative to the existing background noise level at nearby noise sensitive premises.

Simply confirming the noise output does not do this.

Regards Nick

From: Matthew Phillips
Sent: 07 May 2019 12:01
To: Nick Minshall
Subject: FW: P/2019/0253 - Gwersyllt Newsagents

Nick,

Please see below and attached. The drawing confirms the location of the silencer.

Matthew

From: Steve Eltham [mailto:steven@blueprintarchitectural.com]
Sent: 07 May 2019 09:32
To: Matthew Phillips
Subject: P/2019/0253 - Gwersyllt Newsagents

Good Morning Matthew,

Please see the email below and drawing attached with regards to the above application.

Kind regards

Steven Eltham
Architectural Technician
For Blueprint Architectural Services

Tel: 01978 356500
steven@blueprintarchitectural.com

发件人: Fusionhot Commercial Kitchen Design & Instalation <fusionhot1@gmail.com>
发送时间: 2019年5月1日 14:12
收件人: lui yat sheung
主题: Re: P/2019/0253 - Gwersyllt Newsagents

Hi Ringo

The calculation of the in duct noise at 1Mtr distance would be 64db with silencer which is the equivalent of a electric kettle (Moderate noise level)

Thanks
Jenna

On Wed, May 1, 2019 at 10:16 AM lui yat sheung <visontronic@hotmail.com> wrote:

发件人: Steve Eltham <steven@blueprintarchitectural.com>
发送时间: 2019年5月1日 8:47
收件人: lui yat sheung
主题: Fw: P/2019/0253 - Gwersyllt Newsagents

Hi Lui,

Could you please indicated on the attached plan where the fan and silencer will be located?

I have also had another email this morning from the Planning Officer (see below).
Can you please confirm the noise output at a specified distance?

Kind regards

Steven Eltham
Architectural Technician
For Blueprint Architectural Services

Tel: 01978 356500
steven@blueprintarchitectural.com

From: Matthew Phillips
Sent: Wednesday, May 1, 2019 9:28 AM

To: Steve Eltham
Subject: FW: P/2019/0253 - Gwersyllt Newsagents

Steve,

Please see below.

Regards

Matthew Phillips

Planning Control Lead/Arweinydd Rheoli Cynllunio
Environment and Planning/Amgylchedd a Chynllunio
Wrexham County Borough Council/Cyngor Bwrdeistref Sirol Wrecsam
Telephone/Ffôn: 01978 298780

From: Nick Minshall
Sent: 01 May 2019 09:25
To: Matthew Phillips
Subject: RE: P/2019/0253 - Gwersyllt Newsagents

Hello Matthew

There are different noise outputs referred to in the Helios Fan Info attachment. It's not clear what the noise output from the unit is (at 1 metre distance).

The proposed silencer will reduce the output by 7dB.

The applicant should be asked to confirm the noise output at a specified distance.

Regards Nick

From: Matthew Phillips
Sent: 30 April 2019 09:53
To: Nick Minshall
Subject: FW: P/2019/0253 - Gwersyllt Newsagents

Nick,

Please see attached – does this address your comments regarding noise?

Regards

Matthew Phillips

Planning Control Lead/Arweinydd Rheoli Cynllunio
Environment and Planning/Amgylchedd a Chynllunio
Wrexham County Borough Council/Cyngor Bwrdeistref Sirol Wrecsam
Telephone/Ffôn: 01978 298780

From: Steve Eltham [mailto:steven@blueprintarchitectural.com]
Sent: 30 April 2019 08:41

To: Matthew Phillips
Subject: Fw: P/2019/0253 - Gwersyllt Newsagents

Hi Matthew,

Please find attached additional information provided by the client in relation to noise.
I trust these now satisfies your request?

If you require any further information, please don't hesitate to get in contact.

Kind regards

Steven Eltham
Architectural Technician
For Blueprint Architectural Services

Tel: 01978 356500
steven@blueprintarchitectural.com

From: Matthew Phillips [mailto:Matthew.Phillips@wrexham.gov.uk]
Sent: 23 April 2019 14:46
To: Dafydd Edwards
Subject: P/2019/0253 - Gwersyllt Newsagents

Dafydd,

Public Protection have confirmed the details submitted for the above are acceptable in respect of odour control however there is no details in respect of noise. I will be unable to approve the discharge of condition application until further information is forthcoming.

Regards

Matthew Phillips
Planning Control Lead/Arweinydd Rheoli Cynllunio
Environment and Planning/Amgylchedd a Chynllunio
Wrexham County Borough Council/Cyngor Bwrdeistref Sirol Wrecsam
Telephone/Ffôn: 01978 298780

Rydym yn croesawu gohebiaeth yn Gymraeg. Byddwn yn ymateb i unrhyw ohebiaeth yn Gymraeg ac ni fydd hyn yn arwain at unrhyw oedi.

Ewch i weld - mi fedrwch chi dalu, rhoi gwybod, gwneud cais, dweud eich dweud, a dod o hyd i wybodaeth ar-lein yn www.wreccsam.gov.uk. Arbedwch bapur - meddyliwch cyn argraffu!

Mae'r neges e-bost hon ac unrhyw atodiadau wedi eu bwriadu ar gyfer yr unigolyn neu'r sefydliad y?i cyfeirir atynt yn unig. Am yr amodau llawn yngl?n â chynnwys a defnyddio'r neges e-bost hon, ac unrhyw atodiadau, cyfeiriwch at www.wreccsam.gov.uk/top_navigation/disclaimersw.htm

We welcome correspondence in Welsh. We will respond to any correspondence in Welsh and this will not lead to any delay.

Take a look - you can pay, report, request, have your say and find information online at www.wrexham.gov.uk. Save paper - think before you print!

This e-mail message and any attachments are intended solely for the individual or organisation to whom it is addressed. For full conditions in relation to content and use of this e-mail message and any attachments, please refer to www.wrexham.gov.uk/top_navigation/disclaimers.htm

Rydym yn croesawu gohebiaeth yn Gymraeg. Byddwn yn ymateb i unrhyw ohebiaeth yn Gymraeg ac ni fydd hyn yn arwain at unrhyw oedi.


Ewch i weld - mi fedrwch chi dalu, rhoi gwybod, gwneud cais, dweud eich dweud, a dod o hyd i wybodaeth ar-lein yn www.wreccsam.gov.uk. Arbedwch bapur - meddyliwch cyn argraffu!

Mae'r neges e-bost hon ac unrhyw atodiadau wedi eu bwriadu ar gyfer yr unigolyn neu'r sefydliad y'i cyfeirir atynt yn unig. Am yr amodau llawn ynglŷn â chynnwys a defnyddio'r neges e-bost hon, ac unrhyw atodiadau, cyfeiriwch at www.wreccsam.gov.uk/top_navigation/disclaimersw.htm

We welcome correspondence in Welsh. We will respond to any correspondence in Welsh and this will not lead to any delay.

Take a look - you can pay, report, request, have your say and find information online at www.wrexham.gov.uk. Save paper - think before you print!

This e-mail message and any attachments are intended solely for the individual or organisation to whom it is addressed. For full conditions in relation to content and use of this e-mail message and any attachments, please refer to www.wrexham.gov.uk/top_navigation/disclaimers.htm



Virus-free. www.avg.com

--

Kind regards,
Head Office
Jenna

RT.HON. David Curry

Proud to have received an invitation to represent the UK manufacturing and service sector in the 2018/19 parliamentary review as an "OUTSTANDING ORGANISATION" and to help "RAISE STANDARDS IN THE BEST PRACTICE"





Contact Head Office

Fusionhot Ltd
Unit 5
Firefly Square
Plantation Rd
Burscough
Ormskirk
L40 8JT


This email and any files transmitted with it are confidential and intended solely for the use of the individual or entity to whom they are addressed. If you have received this email in error please notify the sender. Fusionhot Ltd is committed to processing personal data correctly and in compliance with GDPR. For more information see our Privacy Policy

Burscough 01704-893945
Morris Direct Dial 01704-829093
Office Mobile 07572623553
Warren Direct Dial 01704-829096
London 020-34090669
Birmingham 0121-2968484
Edinburgh 0131-2853440
Norwich 01603-952700
Mold 01352-755385
Manchester 0161-9892928
Exeter 01392401341
Tynside 0191-6913599




We also have whatsApp on our office mobile.

Web
fusionhot.co.uk
www.facebook.com/fusionhot



Please note all gas and electricity works to be carried out by others unless stated on quotation



Rydym yn croesawu gohebiaeth yn Gymraeg. Byddwn yn ymateb i unrhyw ohebiaeth yn Gymraeg ac ni fydd hyn yn arwain at unrhyw oedi.

Ewch i weld - mi fedrwch chi dalu, rhoi gwybod, gwneud cais, dweud eich dweud, a dod o hyd i wybodaeth ar-lein yn www.wreccsam.gov.uk. Arbedwch bapur - meddyliwch cyn argraffu!

Mae'r neges e-bost hon ac unrhyw atodiadau wedi eu bwriadu ar gyfer yr unigolyn neu'r sefydliad y'i cyfeirir atynt yn unig. Am yr amodau llawn ynglŷn â chynnwys a defnyddio'r neges e-bost hon, ac unrhyw atodiadau, cyfeiriwch at www.wreccsam.gov.uk/top_navigation/disclaimersw.htm

We welcome correspondence in Welsh. We will respond to any correspondence in Welsh and this will not lead to any delay.

Take a look - you can pay, report, request, have your say and find information online at www.wrexham.gov.uk. Save paper - think before you print!

This e-mail message and any attachments are intended solely for the individual or organisation to whom it is addressed. For full conditions in relation to content and use of this e-mail message and any attachments, please refer to www.wrexham.gov.uk/top_navigation/disclaimers.htm